

APPENDIX E

**SUBSURFACE INVESTIGATION AND GEOTECHNICAL
EVALUATION SERVICES**

ATLANTIC TESTING LABORATORIES

DECEMBER 22, 2020



ATLANTIC TESTING LABORATORIES

WBE certified company

Canton
6431 U.S. Highway 11
Canton, NY 13617
315-386-4578 (T)
atlantictesting.com

December 22, 2020

Power Engineers, Inc.
16041 Foster, PO Box 1000
Overlook Park, Kansas 66085

Telephone: 314-851-4050
Email: Dennis.Johnson@powereng.com

Attn: Mr. Dennis Johnson, PE
Senior Project Engineer

Re: Subsurface Investigation and Geotechnical Evaluation Services
Proposed 69kV UG Transmission Circuits
Bridgehampton 9R to Buell 9E Substations
Sag Harbor to East Hampton, Suffolk County, New York
ATL No. CD4827E-01-05-20 Rev. 1

Ladies and Gentlemen:

Enclosed is one (1) electronic copy of the referenced report. ATL appreciates the opportunity to provide geotechnical services for your project.

Please note that upon completion of the subsurface investigation, the boreholes were backfilled with on-site soils. It is important that the backfilled borings be monitored for settlement or subsidence. This will be the responsibility of Power Engineers, Inc. and/or their Client. ATL assumes no liability for loss or damage resulting from borehole settlement.

The soil samples obtained during this investigation will be retained for a period of six months and subsequently discarded, unless otherwise instructed.

Please contact our office should you have any questions or comments on this information, or if we may be of further service. We look forward to our continued association to obtain a successful completion of this project.

Sincerely,
ATLANTIC TESTING LABORATORIES, Limited

Matthew T. Trodler, IE
Project Manager

MTT/mtt

Enclosures

cc: Mr. Bill Stachowiak, PE Power Engineers, Inc. bill.stachowiak@powereng.com

**SUBSURFACE INVESTIGATION
AND
GEOTECHNICAL EVALUATION**

**PROPOSED 69kV UG TRANSMISSION CIRCUIT
BRIDGEHAMPTON 9R TO BUELL 9E SUBSTATIONS
SAG HARBOR TO EAST HAMPTON
SUFFOLK COUNTY, NEW YORK**

POWER ENGINEERS, INC.

**PREPARED FOR: Power Engineers, Inc.
16041 Foster, PO Box 1000
Overlook Park, Kansas 66085**

**PREPARED BY: Atlantic Testing Laboratories, Limited
6431 U.S. Highway 11
Canton, New York 13617**

ATL Report No. CD4827E-01-05-20 Rev. 1

December 22, 2020

TABLE OF CONTENTS

<u>SECTION NUMBER</u>	<u>PAGE</u>
1.0 INTRODUCTION	1
2.0 PROJECT DESCRIPTION	1
3.0 SITE SURFACE CONDITIONS & GEOLOGY	2
4.0 SUBSURFACE INVESTIGATION & SAMPLING METHODOLOGY	3
5.0 SITE SUBSURFACE CONDITIONS	4
5.1 Soil Borings	
5.2 Subsurface Water	
6.0 LABORATORY ANALYSES	6
7.0 GEOTECHNICAL ENGINEERING DISCUSSION & RECOMMENDATIONS	6
7.1 Proposed 69kV UG Transmission Circuit	
7.2 Frost Protection	
7.3 Temporary Slopes	
7.4 Backfill and Compaction Requirements	
7.5 General	
7.6 Dewatering	
7.7 Testing and Inspection	
8.0 LIMITATIONS	10
APPENDICES	
A. Site Location Plan	
B. Boring Location Plans	
C. Subsurface Investigation Logs	
D. Geotechnical Design Parameters Summary Table	
E. Laboratory Test Results	

SUBSURFACE INVESTIGATION AND GEOTECHNICAL EVALUATION

PROPOSED 69kV UG TRANSMISSION CIRCUIT BRIDGEHAMPTON 9R TO BUELL 9E SUBSTATIONS SAG HARBOR TO EAST HAMPTON SUFFOLK COUNTY, NEW YORK

POWER ENGINEERS, INC.

1.0 INTRODUCTION

At the request of Mr. Dennis Johnson, PE, representing Power Engineers, Inc., and in accordance with our proposal (ATL File No. CD998-2388-10-19, dated October 27, 2019), Atlantic Testing Laboratories, Limited (ATL) performed a series of subsurface investigations and a geotechnical evaluation for the referenced project.

The purpose of the investigations was to ascertain the general subsurface soil and water conditions at select locations along the proposed underground transmission route, to evaluate the engineering significance of these findings, and to provide geotechnical recommendations related to the design and installation of underground transmission circuit and vault structures.

The proposed UG transmission project is located along the existing Long Island Power Authority (PSEG-LI)-operated overhead transmission line right-of-way (ROW) between the Bridgehampton and Buell power substations in Sag Harbor and East Hampton, Suffolk County, New York. The geodetic coordinates at the approximate center of the proposed route are N 40°57'58.5" latitude and W 72°15'12.5" longitude. A **Site Location Plan** is included in **Appendix A**. All dimensions and elevations referenced in this report are in units of feet, unless otherwise noted.

2.0 PROJECT DESCRIPTION

It is our understanding the proposed project consists of installing 69 kV underground (UG) transmission cables, via a combination of direct burial, horizontal directional drill (HDD), and jack and bore methods along the existing PSEG-LI-operated overhead transmission line ROW. Based on information provided by Power Engineers, the proposed route is about 5.1 miles long; comprised of approximately 4.5 miles of direct burial cable, approximately ½ mile of horizontal direction drill-installed cable, and approximately 120 feet of jack and bore-installed cable.

The HDD will reportedly be utilized to install the transmission circuit below an environmentally and ecologically sensitive area between Bridgehampton-Sag Harbor Turnpike and Widow-Gavits Road. The jack and bore will facilitate the installation of the circuit, approximately 14 to 20 feet beneath the Long Island Railroad near the Buell Substation. Additionally, solid-splice, vault structures will be installed about every 2,000 lineal feet along the proposed UG transmission route. It is our understanding the precast concrete vault structures will have an approximate 84-square-foot footprint and will bear approximately 10 to 12 feet below grade on a 6-inch layer of compacted stone subbase.

3.0 SITE SURFACE CONDITIONS & GEOLOGY

The proposed underground transmission cable route will generally follow the existing east-west travelling, PSEG-LI-operated overhead transmission line ROW between Bridgehampton-Sag Harbor Turnpike and Cove Hollow Road. The ROW is generally covered with a combination of sand, grass, scrub-brush, small trees, and existing pathways. The overall surface topography fluctuates between approximately elevation 10 and 130, with localized rolling hills and valleys.

The project area is located on Long Island, New York in the Atlantic Coastal Plain Physiographic Region of New York State. Based on the Surficial Geologic Map of New York, Lower Hudson Sheet, 1989, the project area is mantled with a combination of fluvial deposits of outwash sand and gravel and till moraine soils. Outwash sands and gravels are river-born soils generally deposited adjacent to or in front of melting glacier ice. Till moraine deposits are the result of sedimentation of a glacier ice margin, and are generally variably textured in both particle size and sorting, and can exhibit variable permeability. Based on the Geologic Map of New York, Lower Hudson Sheet, 1970, the surficial geology is generally underlain by Upper Cretaceous Age, coastal plain deposits of silty clay, glauconitic sandy clay, sand, and gravel of the Monmouth, Matawan, and Magothy Groups.

Based on 2009 to 2016 tabular and spatial data compiled by the United States Department of Agriculture Natural Resources Conservation Service (USDA NRCS) Web Soil Survey, the project area reportedly contains the following soils:

USDA Soil Symbol	USDA Soil Unit Description
Bd	Berryland mucky sand
Bg	Bridgehampton silt loam, 0-2, 2-6% slopes
Cp	Carver and Plymouth sands, 0-3, 3-15, 15-35% slopes
Cu	Cut and Fill land, gently sloped
Ha	Haven loam, 0-2% slopes
Ma	Made Land
PI	Plymouth , loamy sand, 0-3, 3-8, 8-15% slopes
Ps	Plymouth loamy sand, silty substratum 0-3, 3-8% slopes
Rd	Riverhead sandy loam, 0-3% slopes
Sw	Swansea muck, 0-1% slopes, coastal lowlands

These soils are generally comprised of combinations of sand, sandy loam, silt loam, loamy sand, gravelly sand, and sandy gravel with USCS soil group symbols SM, SP-SM, SP-SC SW, GP, GM, and GW and have a reported “low” to “high” potential for frost action.

Shallow excavations in the project area are generally rated as “not limited” to “somewhat limited” due to soil slope, with the exception of Carver and Plymouth Sands, which are rated “very limited” due to soil slope and unstable excavation side walls; and Berryland and Swansea muck soils due to flooding, ponding, and organic matter.

The soils are generally classified as slightly acidic with pH (soil reaction) values reportedly ranging between 3.6 and 6.0. The risk of corrosion to concrete, based on the sulfate and sodium content, texture, moisture content, and the acidity of the soils identified throughout the project area is generally “high”. The risk of corrosion to uncoated steel based on soil moisture, particle-size distribution, acidity, and electrical conductivity of the soils identified throughout the project area generally ranges from “low” to “high”.

Based on the USDA web soil survey data, the soils identified throughout the project area are USDA Hydrologic Soil Groups A and B, which have high to moderate infiltration rates and high to moderate rates of water transmission.

4.0 SUBSURFACE INVESTIGATION & SAMPLING METHODOLOGY

Nine (9) soil boring locations (BH-1 through BH-9) were selected and staked in the field by representatives of Power Engineers, Inc. The boring surface elevations were not provided to ATL. The **Boring Location Plans**, prepared by Power Engineers, Inc., are included in **Appendix B**.

Prior to advancing and sampling soil borings BH-1, B-2, BH-3, and BH-9, the boreholes were cleared to depths of approximately 3 to 5 feet below the surface utilizing hand excavation equipment.

Four (4) soil borings (BH-1 through BH-3 and BH-9) were advanced utilizing 4-inch inside diameter, flush-joint casing and a tri-cone roller bit using water as the drilling fluid. Four (4) soil borings (BH-4 through BH-7) were advanced using 4¼-inch inside diameter hollow-stem augers. One (1) soil boring (BH-8) was advanced utilizing 3.75-inch inside diameter flush-joint casing using direct push and percussion-impact methods (Geoprobe® GH63 Percussion Hammer). Soil sampling and standard penetration testing was performed utilizing a 2-inch outside diameter split spoon sampler and automatic drop hammer in accordance with ASTM D 1586. Soil sampling was performed continuously to a depth of approximately 16 feet and at 5-foot intervals thereafter to boring termination at depths ranging from 16 to 101 feet. A 3-inch, brass-lined split spoon sampler was utilized at boring locations BH-1 through BH-3, BH-8, and BH-9 to collect samples for laboratory thermal resistivity testing, at depths selected by Power Engineers.

Additionally, to facilitate laboratory thermal resistivity testing, bulk soil samples were collected from hollow-stem auger cuttings at each soil boring location at depths of 5 and 10 feet below the surface. Select bulk soil samples were submitted to ATL’s geotechnical laboratory, with representative portions relinquished to GeoTherm USA’s Houston, Texas laboratory for subsequent analyses. The laboratory thermal resistivity test results will be provided to Power Engineers by GeoTherm USA under a separate cover.

The thermal resistivity sample locations, collection method, and depths are summarized in the following table:

Thermal Resistivity Sample Location Summary Table

Boring No.	Sample No.	Sample Depth (ft)	Sample Type
BH-1	BS-1	5 – 10	Bulk ⁽¹⁾
	SS-8	21 – 23	3-inch SS ⁽²⁾
	SS-19	74 – 76	
	SS-24	99 – 101	
BH-2	BS-1	0 – 5	Bulk ⁽¹⁾
	SS-14	50 – 52	3-inch SS ⁽²⁾
	SS-25	100 – 102	
BH-3	BS-1	5 – 10	Bulk ⁽¹⁾
	SS-8	20 – 22	3-inch SS ⁽²⁾
	SS-20	75 – 77	
BH-4	BS-1	0 – 5	Bulk ⁽¹⁾
	BS-2	5 – 10	Bulk ⁽¹⁾

Boring No.	Sample No.	Sample Depth (ft)	Sample Type
BH-5	BS-1	0 – 5	Bulk ⁽¹⁾
	BS-2	5 – 10	Bulk ⁽¹⁾
BH-6	BS-1	0 – 5	Bulk ⁽¹⁾
	BS-2	5 – 10	Bulk ⁽¹⁾
BH-7	BS-1	0 – 5	Bulk ⁽¹⁾
	BS-2	5 – 10	Bulk ⁽¹⁾
BH-8	BS-1	5 – 10	Bulk ⁽¹⁾
	SS-9	19 – 21	3-inch SS ⁽²⁾
BH-9	BS-1	5 – 10	Bulk ⁽¹⁾
	SS-6	18 – 20	3-inch SS ⁽²⁾
	SS-11	38 – 40	

⁽¹⁾ Bulk sample collected utilizing hollow-stem augers

⁽²⁾ Sample collected utilizing 3-inch, brass-lined split spoon sampler

The soil samples were classified in the laboratory by an engineering technician in general accordance with the Burmister Soil Classification System. The 2-inch and 3-inch split spoon samplers do not recover particles larger than 1³/₈-inch and 2¹/₂-inch in nominal dimension; therefore, the soil classifications may not be representative of the entire soil matrix. The laboratory classifications and the standard penetration test (SPT) results are presented on the **Subsurface Investigation Logs** included in **Appendix C**.

The boreholes were backfilled with on-site soils upon completion. It is important that the backfilled borings be monitored for settlement or subsidence. This will be the responsibility of Power Engineers, Inc. and/or their Client. ATL assumes no liability for loss or damage resulting from borehole settlement.

5.0 SITE SUBSURFACE CONDITIONS

The following description of subsurface conditions is based on the subsurface soil and water conditions encountered during these subsurface investigations performed during the periods of May 12 and 19, September 22 and 24, and November 11, 2020. Actual subsurface conditions will vary between the borehole locations in both the horizontal and vertical dimensions. Detailed subsurface descriptions are provided on the Subsurface Investigation Logs. The surficial organic material thicknesses presented on the soil boring logs should not be utilized to estimate material quantities for construction.

5.1 Soil Borings

Soil borings BH-1 through BH-9 generally encountered similar conditions across the project site. The soil borings generally encountered very loose (SPT N-values less than 4) to medium compact (SPT N-values 10 to 30) sand with lesser proportions of silt, gravel, and organic material that extended to depths ranging from 4 to 8 feet below the surface. The surficial materials were generally underlain by non-plastic, coastal plains soils comprised predominantly of loose to compact (SPT N-values 30 to 50) sand with lesser proportions of silt, gravel, and cobbles that extended to boring termination at depths ranging from 16 to 42 feet below the surface in borings BH-4 through BH-9, and to depths ranging from approximately 22 to 42 feet in borings BH-1, BH-2, and BH-3.

Underlying the medium compact silty, gravelly sand at a depth of approximately 27 feet, soil boring BH-1 encountered medium compact silt and fine sand that extended to a depth of approximately 47 feet, followed by layers of compact (SPT N-values 30 to 50) to very compact (SPT N-values greater than 50) silty sand, and very compact sand and gravel that extended to boring termination at a depth of 101 feet below the surface. The exceptions are discrete layers of medium compact to very compact clayey sand with silt encountered between depths of approximately 52 and 57 feet, and 82 and 87 feet below the surface.

Underlying the medium compact gravelly sand with silt at a depth of approximately 22 feet, soil boring BH-2 encountered varying layers of medium compact to compact sand with intermittent zones of gravel and trace clay that extended to a depth of approximately 82 feet, underlain by compact silty sand with lesser proportions of gravel that extended to boring termination at a depth of 102 feet below the surface.

Underlying the loose to medium compact silty sand with gravel at a depth of approximately 42 feet, soil boring BH-3 encountered medium compact to compact sandy and silt containing isolated zones of trace clay that extended to a depth of approximately 78 feet below the surface, underlain by medium compact to compact silty sand with varying proportions of clay and gravel that extended to boring termination at a depth of 101 feet below the surface.

Cobbles and cobble fragments were encountered within the sand and gravel layers throughout the depths investigated.

Trace amounts of wood fragments were encountered in soil borings BH-4, BH-5, and BH-8 at depths ranging from approximately 2 to 14 feet below the surface.

5.2 Subsurface Water

Subsurface water measurements and observations were performed during the subsurface investigation through cased and open boreholes. The recovered soil samples were also classified for coloration and relative moisture conditions.

Based on water measurements, subsurface water was recorded at depths ranging from approximately 9.7 to 42.4 feet below the surface in soil borings BH-1, BH-2, BH-3, and BH-9; however, these readings were likely affected by water utilized to advance the boreholes. The recovered soil samples were generally classified as moist to wet to depths of approximately 18 and 9 feet in borings BH-2 and BH-3, respectively, and to termination in borings BH-1 and BH-9 at depths of 101 and 42 feet, respectively. Below depths of 18 and 9 feet in soil borings BH-2 and BH-3, the recovered soil samples were generally classified as wet to saturated.

Based on the driller's observations and soil moisture content, freestanding water was not encountered in soil borings BH-4 through BH-8 to the depths investigated. The recovered soil samples were generally classified as moist to the depths investigated.

Since the borings were generally backfilled upon completion, the water levels may not have had sufficient time to stabilize in the open boreholes. Perched groundwater may be encountered within foundation and utility excavations, especially during wetter periods of the year. It is anticipated that perched water encountered in shallow excavations may be controlled by pumping from sumps installed around the perimeter of the excavations.

Fluctuations in water levels may occur due to seasonal and climatic variations, changes in surface runoff patterns, tidal effects of the Atlantic Ocean, water elevation variations in Long Pond, construction activity, and subsequent development of the site along with other interrelated factors.

6.0 LABORATORY ANALYSES

Select soil samples were submitted to ATL's geotechnical laboratory for the following physical analyses:

- ◆ Twenty-Six (26) Water Content Determination of Soil (ASTM D 2216)
- ◆ Twenty-Three (23) Particle Size Analysis without Hydrometer (ASTM D 422)
- ◆ One (1) Particle Size Analysis with Hydrometer (ASTM D 422)
- ◆ Four (4) Atterberg Limits Determination of Soils (ASTM D 4318)
- ◆ Seven (7) Laboratory Compaction Characteristics of Soil using the Modified Efforts (ASTM D 1557)

The test results are presented on the subsurface investigation logs and included in **Appendix E, Laboratory Test Reports**.

7.0 GEOTECHNICAL ENGINEERING DISCUSSION

The Geotechnical Engineering Discussion is based on information provided by Power Engineers, Inc., PSEG-LI, and the subsurface conditions outlined in this report. At the time of report issuance, it is our understanding that the project will utilize a combination of direct burial, horizontal directional drill (HDD), and jack and bore methods to install the proposed 69 kV circuit.

7.1 Proposed 69kV UG Transmission Circuit

7.1.1 Site Preparation

Site work will require the removal of any surficial topsoil, organic material, scrub-brush, and trees along the proposed direct burial route, and within the footprint of the precast, concrete vault structures.

In planning excavations adjacent to existing roadways, structures and utilities, care should be taken to locate and maintain their stability. The project should be designed to minimize disturbance to existing structures and utilities.

7.1.2 Direct-Burial Cable and Solid-Splice Vault Structures

Based on our evaluation of the subsurface conditions and the information provided, the proposed solid-splice vault structures may be founded on a shallow foundation system provided the recommendations contained in this report are followed.

The proposed vault structure excavations should be advanced to the proposed depths of 10 to 12 feet below grade. Based on information disclosed through the soil borings performed for the project, it is anticipated the vault structure excavations will encounter medium compact sand with lesser proportions of gravel, silt, and cobbles.

Trace amounts of wood fragments were encountered in soil borings BH-4, BH-5, and BH-8 at depths ranging from approximately 2 to 14 feet below the surface. These materials may exist at other locations, elevations, and concentrations throughout the project site. Deleterious organic material encountered at the planned bottom of excavations for the proposed structures should be over excavated and replaced with compacted Granular Fill or other material specified by the Design Engineer. All fill should be placed and compacted in accordance with Section 7.4 of this report, or as specified by the Design Engineer.

All foundation excavations should be continuously monitored by a Geotechnical Engineer to verify subgrade stability and to ensure that adequate soil bearing capacity is obtained.

The stone subbase should be placed on stable foundation subgrade soils and compacted with a minimum of four passes of a dual-drum, walk-behind vibratory roller; a Wacker DPU 6055 vibrating plate tamper; or equivalent, under the direction of the Geotechnical Engineer. The crushed stone will provide a stable working surface and dewatering media if ground or surface water enters the excavation during foundation subgrade preparation and construction.

Shallow foundations supported on a 6-inch layer of compacted, stone subbase overlying stable, native sand soils may be designed using an allowable soil bearing capacity of 2000 psf, provided the recommendations presented in this report are followed.

A detailed settlement analysis was outside the scope of this investigation; however, total and differential post-construction settlement less than 1-inch and ½-inch, respectively, are estimated.

7.1.3 HDD and Jack/Bore Installations

The site soils in the area of the proposed horizontal directional drilling, and jack and bore installations are predominantly comprised of loose to medium compact silty sand with gravel, and medium compact, non-plastic sandy silt, underlain by compact to very compact silty sand and gravel with isolated layers of medium compact clayey sand. Cobbles and cobble fragments were encountered within the soil borings throughout the depths investigated.

The loose to medium compact, in-situ granular soils will have a tendency to flow into open excavations and collapse within uncased boreholes, especially in the presence of surface and subsurface water, without adequate excavation support and/or dewatering. Excavation support and/or dewatering methods should be designed by the contractor's engineer to maintain the stability of the excavation sidewalls and bottom. The contractor should be responsible for the means and methods of advancing site work excavations and directional boreholes.

The empirical soil parameters contained in the **Geotechnical Design Parameters Summary Tables** included in **Appendix D** may be used for horizontal directional drill (HDD) and jack and bore design and installation.

7.2 Frost Protection

Shallow foundations requiring frost protection should be founded a minimum of 3.5 feet below final exterior grade.

7.3 Temporary Slopes

It is our understanding that temporary cut and fill slopes on the order of 6 to 7 feet high will be required in the area of ATL soil boring BH-1 and the Bridgehampton Substation to facilitate the western HDD installation pits.

Cut/fill slopes completed within the in-situ medium compact sand soils should be limited to 2H:1V or flatter for the temporary HDD work in the area of the Bridgehampton Substation.

Fill placed on existing slopes greater than 4H:1V should be benched into the existing slope to reduce the tendency of sliding along the existing slope surface. The slope face should be overbuilt and trimmed back to the final slope inclination or compacted with a hoe tamper to provide a stable slope face.

Straw matting, or other temporary stabilization measures approved by the engineer, should be placed along slope faces to minimize slope erosion.

Site surface grading should be designed to convey surface water away from slopes and open excavations. Surface and/or groundwater runoff should be collected and diverted around the slope through the use of interceptor trenches or surface swales.

Based on soil boring BH-1, groundwater appears to be below the cut depth of 6 to 7 feet; however, stone fill Rip-Rap swales may be necessary to stabilize soils, if shallow perched groundwater seepage is observed within exposed slopes. A granular bedding or non-woven geotextile fabric should be placed between stone fill and native subgrade soils to prevent migration of the soils into the stone fill.

7.4 Backfill and Compaction Requirements

The on-site soils may be utilized as transmission cable trench backfill and exterior foundation backfill, provided all deleterious organic and oversize material (particles larger than 4 inches in diameter) are removed, the material is properly moisture conditioned, and meets the thermal resistivity requirements for the UG cables, as determined by the Design Engineer. Granular Fill, or other material approved by the Design Engineer, should be utilized beneath structures.

All controlled fill and backfill should be placed and compacted in lifts not exceeding eight inches in loose thickness, at a moisture content of $\pm 2\%$ of the Optimum Moisture Content, and to densities in excess of 95%, as determined by ASTM D1557, or as directed by the Geotechnical Engineer.

Compaction should be performed with vibratory rollers unless there is concern for damage to adjacent structures or underground utilities.

Granular Fill should consist of a clean, screened, crushed, or bank-run gravel conforming to the following gradation:

Sieve Size	Percent Passing
4"	100
1/4"	35-65
#200	0-10

The soil parameters presented in the following table may be used for the following backfill materials.

Table of Soil Properties

Soil Property	On-site, Gravelly Sand	Granular Fill
Angle of Internal Friction (°)	30	32
Active Earth Coefficient (K_a)*	0.33	0.31
At Rest Earth Coefficient (K_o)*	0.50	0.47
Passive Earth Coefficient (K_p)*	3.00	3.25
Ultimate Coefficient of Sliding Friction	0.38	0.41
Moist Unit Weight (pcf)	120-130	130-140

*The Rankine earth pressure coefficients (ultimate values) are for level backfill placed in a fully drained condition.

7.5 General

Heavy construction vehicles should be limited on exposed subgrades, especially during wetter periods of the year.

Perched subsurface water, sloughing granular soils, and cobbles may be encountered in utility and site work excavations.

Care must be exercised to locate and maintain the stability of all adjacent structures and utilities that are to remain in-place.

It will be the contractor's responsibility to maintain adequate water control at all times. Project specifications should clearly indicate that standing water, and/or saturated, unstable soil conditions will not be tolerated in areas to receive foundations or utilities. The project specifications should state that the contractor will not be reimbursed for extras related to the control of water.

All dewatering activities must comply with New York State Department of Environmental Conservation (NYSDEC) storm water discharge and PSEG-LI requirements for construction.

7.6 Dewatering

It will be the contractor's responsibility to maintain adequate water control at all times. Project specifications should clearly indicate that standing water, and/or saturated, unstable soil conditions will not be tolerated in areas to receive foundations or utilities. The project specifications should state that the contractor will not be reimbursed for extras related to the control of water.

All dewatering activities must comply with New York State Department of Environmental Conservation (NYSDEC), and/or applicable federal or local storm water discharge requirements for construction.

7.7 Testing and Inspection

Subgrade preparation and foundation installations should be continuously observed by an experienced Geotechnical Engineer, and/or their representative, familiar with the subsurface conditions and analysis described in this report. The engineer will be required to assess any unusual conditions and to ensure that adequate bearing capacities and proper foundation installation requirements are achieved.

All backfilling, placement of fill, compaction of in-situ soils, and concrete construction should be inspected by an Independent Testing Laboratory, which conforms to ASTM E-329, "The Standard Practice for use in the Evaluation of Testing and Inspection Agencies as Used in Construction". It should be the Independent Testing Laboratory's responsibility to monitor construction practices to determine if they are in accordance with the project documents.

The final site plans and project specifications should be reviewed by ATL, as the Geotechnical Engineer of Record, to verify that there has not been a misinterpretation of this report and/or ATL's understanding of the project.

8.0 LIMITATIONS

The subsurface investigation logs and this report in its entirety should be provided to the contractors for information and interpretation. The subsurface investigation logs may not be representative of the entire site subsurface condition, but only what was encountered at the individual test locations at the time of the investigation. The subsurface soil and groundwater conditions may be different from those described on the subsurface investigation logs.

This report was prepared to present the findings of our subsurface investigation and engineering evaluation, and to outline concepts to be utilized in foundation design and construction. These concepts may require alterations to meet the specific design and economic considerations for this project.

Prepared by:



Matthew T. Trodler, IE
Project Manager


Reviewed by:



Brian T. Barnes, PE
Senior Engineer

MTT/BTB/mtt

APPENDIX A
SITE LOCATION PLAN



SITE LOCATION PLAN

Drawn by:
MTT

Scale:
As Noted

Project No.:
CD4827

Date:
May-Nov 2020


**Proposed 69 kV UG Transmission Circuit
Bridgehampton 9R to Buell 9E Substations
Sag Harbor, Suffolk County, New York**




ATLANTIC TESTING LABORATORIES, Limited

Albany, NY	Binghamton, NY	Canton, NY	Elmira, NY	Plattsburgh, NY
Poughkeepsie, NY	Syracuse, NY	Rochester, NY	Utica, NY	Watertown, NY


APPENDIX B
BORING LOCATION PLANS



PLAN
SCALE: 1"=20'



1. THE UTILITIES AND MINERAL FEATURES SHOWN HEREON ARE BASED ON FIELD SURVEYS, AERIAL PHOTOGRAPHY AND RECORD DOCUMENTS. OTHER FACILITIES MAY EXIST NOT DISCOVERED THROUGH THE RECORD CHECK. THE CONTRACTOR SHALL VERIFY THE EXACT LOCATION, BOTH HORIZONTAL AND VERTICAL, OF ALL UTILITIES THROUGH THE APPROPRIATE UTILITY COMPANIES. CALL BEFORE YOU DIG, 811 OR 1-800-272-4480.
2. VERTICAL LOCATION OF SUBSURFACE UTILITY LINES ARE BASED ON ASSUMED DEPTHS AND MAY VARY FROM THE ACTUAL VERTICAL LOCATIONS.
3. VEGETATION TO BE REMOVED BY CIVIL CONTRACTOR AS NEEDED AND RESTORED TO ORIGINAL CONDITION.





Know what's **below**.
Call before you dig.



A	02/28/20	ISSUES FOR REVIEW	JRD	CJS	DE
REV	DATE	DESCRIPTION	DRAWN	REVIEW	APPROVED


DATE		TIME		LOCATION		DESCRIPTION		REMARKS	
1	10/10/10	1:00		USED FOR 30 MIN					
NO.	DATE	TIME		DESCRIPTION		DOWN BY	DOWN BY	REVIEWED	APPROVED

Long Island Power Authority BRIDGEHAMPTON TO BUELL SUBSTATION			
69KV TRANSMISSION LINE			
BRIDGEHAMPTON TO BUELL UNDERGROUND TRANSMISSION CIRCUIT PLAN & PROFILE SHEET 1 OF 46			
 PSEG LONG ISLAND 175 East 64 Country Road Hicksville, New York			
SCALE AS SHOWN		VENDOR DWG. NO.	
DRAWING NO. F101	SHEET NO.		*
SYSTEM DATA: available			CARRIER NO.



NOTES:

1. THE UTILITIES AND NATURAL FEATURES SHOWN HEREON ARE BASED ON FIELD SURVEYS, AERIAL PHOTOGRAPHY AND RECORD DOCUMENTS. OTHER FACILITIES MAY EXIST NOT DISCOVERED THROUGH THE RECORD CHECK. THE CONTRACTOR SHALL VERIFY THE EXACT LOCATION, BOTH HORIZONTAL AND VERTICAL, OF ALL UTILITIES THROUGH THE APPROPRIATE UTILITY COMPANIES. CALL BEFORE YOU DIG, 811 OR 1-800-272-4480.
2. VERTICAL LOCATION OF SUBSURFACE UTILITY LINES ARE BASED ON ASSUMED DEPTHS AND MAY VARY FROM THE ACTUAL VERTICAL LOCATIONS.
3. VEGETATION TO BE REMOVED BY CIVIL CONTRACTOR AS NEEDED AND RESTORED TO ORIGINAL CONDITION.



REV	DATE	DESCRIPTION	BY	CHKD	APPD
1	05/28/20	ISSUED FOR REVIEW	JRD	CJS	SEJ

PROJ. NO. L. 99900


REV	DATE	DESCRIPTION	BY	CHKD	APPD
1	05/28/20	ISSUED FOR REVIEW	JRD	CJS	SEJ

Long Island Power Authority
BRIDGEHAMPTON TO BUELL SUBSTATION
69KV TRANSMISSION LINE
BRIDGEHAMPTON TO BUELL
UNDERGROUND TRANSMISSION CIRCUIT
PLAN & PROFILE SHEET 3 OF 46


PSEG LONG ISLAND
170 East Old Country Road
Roseland, New York

SCALE: AS SHOWN
DRAWING NO. **F103**
SHEET NO. *****
REVISION **0**

DATE: 05/28/20



PLAN
SCALE: 1"=20'



NOTES:

- THE UTILITIES AND NATURAL FEATURES SHOWN HEREON ARE BASED ON FIELD SURVEYS, AERIAL PHOTOGRAPHY AND RECORD DOCUMENTS. OTHER FACILITIES MAY EXIST NOT DISCOVERED THROUGH THE RECORD CHECK. THE CONTRACTOR SHALL VERIFY THE EXACT LOCATION, BOTH HORIZONTAL AND VERTICAL, OF ALL UTILITIES THROUGH THE APPROPRIATE UTILITY COMPANIES. CALL BEFORE YOU DIG, 811 OR 1-800-372-4480.
- VERTICAL LOCATION OF SUBSURFACE UTILITY LINES ARE BASED ON ASSUMED DEPTHS AND MAY VARY FROM THE ACTUAL VERTICAL LOCATIONS.
- VEGETATION TO BE REMOVED BY CIVIL CONTRACTOR AS NEEDED AND RESTORED TO ORIGINAL CONDITION.

0 10 20 40 60 FEET
HORIZONTAL SCALE 1"= 20'

0 2 4 8 12 FEET
VERTICAL SCALE: 1"= 4'

811
Know what's below.
Call before you dig.

PRELIMINARY
FOR REFERENCE ONLY

POWER ENGINEERS

REV	DATE	DESCRIPTION	BY	CHKD	APPD
1	05/28/20	ISSUED FOR PERMIT			

REV	DATE	DESCRIPTION	BY	CHKD	APPD
1	05/28/20	ISSUED FOR PERMIT			

PROJECT NO. L. 99900

DRAWING NO. F106

SCALE AS SHOWN


170 East Old Country Road
Bridgewater, New York

BRIDGEHAMPTON TO BUELL
UNDERGROUND TRANSMISSION CIRCUIT
PLAN & PROFILE SHEET 6 OF 46

LONG ISLAND
PSEG


05/28/20

0




PLAN

SCALE: 1"=20'



NOTES:

1. THE UTILITIES AND NATURAL FEATURES SHOWN HEREON ARE BASED ON FIELD SURVEYS, AERIAL PHOTOGRAPHY AND RECORD DOCUMENTS. OTHER FACILITIES MAY EXIST NOT DISCOVERED THROUGH THE RECORD CHECK. THE CONTRACTOR SHALL VERIFY THE EXACT LOCATION, BOTH HORIZONTAL AND VERTICAL, OF ALL UTILITIES THROUGH THE APPROPRIATE UTILITY COMPANIES. CALL BEFORE YOU DIG, 811 OR 1-800-272-4480.
2. VERTICAL LOCATION OF SUBSURFACE UTILITY LINES ARE BASED ON ASSUMED DEPTHS AND MAY VARY FROM THE ACTUAL VERTICAL LOCATIONS.
3. VEGETATION TO BE REMOVED BY CIVIL CONTRACTOR AS NEEDED AND RESTORED TO ORIGINAL CONDITION.




PRELIMINARY
FOR REFERENCE ONLY



REV	DATE	DESCRIPTION	BY	CHK	APP
1	05/28/20	ISSUED FOR REVIEW			

REV	DATE	DESCRIPTION	BY	CHK	APP
1	05/28/20	ISSUED FOR REVIEW			


Long Island Power Authority BRIDGEHAMPTON TO BUELL SUBSTATION 69KV TRANSMISSION LINE BRIDGEHAMPTON TO BUELL UNDERGROUND TRANSMISSION CIRCUIT PLAN & PROFILE SHEET 8 OF 46 PSEG LONG ISLAND 175 East Old Country Road Roseland, New York	
SCALE AS SHOWN	UNION SHEET NO.
DRAWING NO. F108	REVISION 0
OWNER AND NUMBER	CHECKED BY FOLDER NO.






300-184-01-4.3
L=12913-cp379
137 Stephen Hands Path
Holdings LLC

300-182-02-8.1
L=12177-cp705
Town of East Hampton




PLAN
SCALE: 1"=20'



NOTES:

1. THE UTILITIES AND NATURAL FEATURES SHOWN HEREON ARE BASED ON FIELD SURVEYS, AERIAL PHOTOGRAPHY AND RECORD DOCUMENTS. OTHER FACILITIES MAY EXIST NOT DISCOVERED THROUGH THE RECORD CHECK. THE CONTRACTOR SHALL VERIFY THE EXACT LOCATION, BOTH HORIZONTAL AND VERTICAL, OF ALL UTILITIES THROUGH THE APPROPRIATE UTILITY COMPANIES. CALL BEFORE YOU DIG, 811 OR 1-800-272-4480.
2. VERTICAL LOCATION OF SUBSURFACE UTILITY LINES ARE BASED ON ASSUMED DEPTHS AND MAY VARY FROM THE ACTUAL VERTICAL LOCATIONS.
3. VEGETATION TO BE REMOVED BY CIVIL CONTRACTOR AS NEEDED AND RESTORED TO ORIGINAL CONDITION.



PRELIMINARY
FOR REFERENCE ONLY





REV	DATE	DESCRIPTION	BY	CHKD	APPD
1	05/08/20	ISSUED FOR PERMIT	JLD	CJS	SEJ


PROJ. NO. L 99900

REV	DATE	DESCRIPTION	BY	CHKD	APPD
1	05/08/20	ISSUED FOR PERMIT	JLD	CJS	SEJ

Long Island Power Authority BRIDGEHAMPTON TO BUELL SUBSTATION	
60KV TRANSMISSION LINE	
BRIDGEHAMPTON TO BUELL UNDERGROUND TRANSMISSION CIRCUIT PLAN & PROFILE SHEET 36 OF 46	
PSEG LONG ISLAND 170 East Old Country Road Roseland, New York	
SCALE AS SHOWN	UNION SHEET NO.
DRAWING NO. F136	REVISION 0
SHEET NO. FOLDER NO.	




PLAN
SCALE: 1"=20'



NOTES:

1. THE UTILITIES AND NATURAL FEATURES SHOWN HEREON ARE BASED ON FIELD SURVEYS, AERIAL PHOTOGRAPHY AND RECORD DOCUMENTS. OTHER FACILITIES MAY EXIST NOT DISCOVERED THROUGH THE RECORD CHECK. THE CONTRACTOR SHALL VERIFY THE EXACT LOCATION, BOTH HORIZONTAL AND VERTICAL, OF ALL UTILITIES THROUGH THE APPROPRIATE UTILITY COMPANIES. CALL BEFORE YOU DIG, 811 OR 1-800-272-4480.
2. VERTICAL LOCATION OF SUBSURFACE UTILITY LINES ARE BASED ON ASSUMED DEPTHS AND MAY VARY FROM THE ACTUAL VERTICAL LOCATIONS.
3. VEGETATION TO BE REMOVED BY CIVIL CONTRACTOR AS NEEDED AND RESTORED TO ORIGINAL CONDITION.





REV	DATE	DESCRIPTION	BY	CHKD BY	REV	DATE	DESCRIPTION	BY	CHKD BY
1	05/08/20	ISSUED FOR REVIEW	JRD	CJS	36.1				

PROJ. NO. L. 99900


REV	DATE	DESCRIPTION	BY	CHKD BY	REV	DATE	DESCRIPTION	BY	CHKD BY
1	05/08/20	ISSUED FOR REVIEW	JRD	CJS	36.1				

Long Island Power Authority BRIDGEHAMPTON TO BUELL SUBSTATION 60KV TRANSMISSION LINE BRIDGEHAMPTON TO BUELL UNDERGROUND TRANSMISSION CIRCUIT PLAN & PROFILE SHEET 40 OF 46 PSEG LONG ISLAND 170 East Old Country Road Roseland, New York	
SCALE AS SHOWN F140	DESIGN NO. * REVISION 0
SHEET NO. *	FOLDER NO. 0



NOTES:

1. THE UTILITIES AND NATURAL FEATURES SHOWN HEREON ARE BASED ON FIELD SURVEYS, AERIAL PHOTOGRAPHY AND RECORD DOCUMENTS. OTHER FACILITIES MAY EXIST NOT DISCOVERED THROUGH THE RECORD CHECK. THE CONTRACTOR SHALL VERIFY THE EXACT LOCATION, BOTH HORIZONTAL AND VERTICAL, OF ALL UTILITIES THROUGH THE APPROPRIATE UTILITY COMPANIES. CALL BEFORE YOU DIG, 811 OR 1-800-272-4480.
2. VERTICAL LOCATION OF SUBSURFACE UTILITY LINES ARE BASED ON ASSUMED DEPTHS AND MAY VARY FROM THE ACTUAL VERTICAL LOCATIONS.
3. VEGETATION TO BE REMOVED BY CIVIL CONTRACTOR AS NEEDED AND RESTORED TO ORIGINAL CONDITION.




PRELIMINARY
FOR REFERENCE ONLY




NO.	DATE	REVISION	BY	CHKD.	APPD.
1	05/08/20	ISSUED FOR REVIEW			

NO.	DATE	REVISION	BY	CHKD.	APPD.
1	05/08/20	ISSUED FOR REVIEW			

Long Island Power Authority BRIDGEHAMPTON TO BUELL SUBSTATION 69KV TRANSMISSION LINE BRIDGEHAMPTON TO BUELL UNDERGROUND TRANSMISSION CIRCUIT PLAN & PROFILE SHEET 43 OF 46 PSEG LONG ISLAND 170 East Old Country Road Roseland, New York SCALE AS SHOWN UNION PROJECT NO. SHEET NO. F143 * 0 SYSTEM AND NUMBER CHART NO. FOLDER NO.	
---	--




PLAN
SCALE: 1"=20'



NOTES:

1. THE UTILITIES AND NATURAL FEATURES SHOWN HEREON ARE BASED ON FIELD SURVEYS, AERIAL PHOTOGRAPHY AND RECORD DOCUMENTS. OTHER FACILITIES MAY EXIST NOT DISCOVERED THROUGH THE RECORD CHECK. THE CONTRACTOR SHALL VERIFY THE EXACT LOCATION, BOTH HORIZONTAL AND VERTICAL, OF ALL UTILITIES THROUGH THE APPROPRIATE UTILITY COMPANIES. CALL BEFORE YOU DIG, 811 OR 1-800-272-4480.
2. VERTICAL LOCATION OF SUBSURFACE UTILITY LINES ARE BASED ON ASSUMED DEPTHS AND MAY VARY FROM THE ACTUAL VERTICAL LOCATIONS.
3. VEGETATION TO BE REMOVED BY CIVIL CONTRACTOR AS NEEDED AND RESTORED TO ORIGINAL CONDITION.



REV	DATE	DESCRIPTION	BY	CHKD	APP'D
1	05/08/20	ISSUED FOR REVIEW	JMD	CJS	SEJ

PROJ. NO. L. 99900

REV	DATE	DESCRIPTION	BY	CHKD	APP'D
1	05/08/20	ISSUED FOR REVIEW	JMD	CJS	SEJ

Long Island Power Authority
BRIDGEHAMPTON TO BUELL SUBSTATION
69KV TRANSMISSION LINE
BRIDGEHAMPTON TO BUELL
UNDERGROUND TRANSMISSION CIRCUIT
PLAN & PROFILE SHEET 44 OF 46

PSEG LONG ISLAND
170 East Old Country Road
Roseland, New York

SCALE: AS SHOWN
SHEET NO. F144
DRAWING NO. *
REVISION 0
SYSTEM AND NUMBER CHASSET NO. FOLDER NO.

APPENDIX C

SUBSURFACE INVESTIGATION LOGS

ATLANTIC TESTING LABORATORIES, Limited

Subsurface Investigation

Client: Power Engineers
 Project: Subsurface Investigation
PSEG - L1 Bridgehampton 9R to Buell 9E Substations
Sag Harbor, New York

Report No.: CD4827E-01-12-20
 Boring Location: See Boring Location Plan
Offset approximately 50' southwest of original boring
location due to conflict with buried utilities.
 Start Date: 5/12/2020 Finish Date: 5/14/2020

Boring No.: BH-1 Sheet 1 of 4
 Coordinates _____ Sampler Hammer _____
 Latitude _____ Weight: 140 lbs.
 Longitude _____ Fall: 30 in.
 Hammer Type: Automatic
 Ground Elev.: _____ Boring Advance By: _____
HW (4") Casing/3 7/8" Wet Rotary

Date	Time	Depth	Casing
5/12/2020	PM	*6.4'	9.0'
5/13/2020	PM	*22.3'	64.0'
5/14/2020	AM	42.4'	64.0'
5/14/2020	PM	*28.7'	64.0'
5/14/2020	PM	*17.2'	CAVED

Borehole caved at 25.7 feet. *May be affected by water utilized to advance the borehole.

DEPTH	METHOD OF ADVANCE	SAMPLE NO.	DEPTH OF SAMPLE		SAMPLE TYPE	BLOWS ON SAMPLER PER 6" 2" O.D. SAMPLER	DEPTH OF CHANGE	CLASSIFICATION OF MATERIAL	Recovery (Inches)
			From	To					
1	C								
2	A								
3	S								
4	I								
5	N								
6	G	1	3.0	5.0	SS	2 3 4 4	5.5	Hand cleared to 3.0 feet and began sampling. Brown cmf SAND; trace f GRAVEL; trace SILT (moist, non-plastic) Encountered COBBLE fragments from 3.0 to 23.0 feet.	16
7		2	5.0	7.0	SS	4 11 14 18		Brown cmf SAND; little c+f GRAVEL; trace SILT (moist, non-plastic)	18
8		3	7.0	9.0	SS	4 13 11 12		Brown cmf SAND; little cf GRAVEL; trace SILT (moist, non-plastic)	10
9		4	9.0	11.0	SS	7 12 14 14		Brown cmf SAND; trace f GRAVEL; trace SILT (moist, non-plastic)	10
10		5	11.0	13.0	SS	11 12 13 21		Brown cmf SAND; trace f GRAVEL; trace SILT (moist, non-plastic)	14
11		6	13.0	15.0	SS	5 9 10 12		Brown cmf SAND; trace f GRAVEL; trace SILT (moist, non-plastic)	7
12									
13									
14									
15									
16									
17							17.0		
18									
19		7	19.0	21.0	SS	7 4 4 7		Brownish-Reddish-Grey cmf SAND; little SILT; trace f GRAVEL (moist, non-plastic)	12
20		8	21.0	23.0	SS	8 8 11 12		Light Brown cmf SAND; trace f GRAVEL; trace SILT (moist, non-plastic)	14
21									
22									
23									
24		9	24.0	26.0	SS	4 4 6 9		Light Brownish-Orangish-Grey cmf SAND; little SILT (moist,	10
25									

SS Split Spoon Sample
 NX Rock Core
 SH Undisturbed Sample (Shelby Tube)
 Estimated Groundwater

Drillers: Scott McGregor: Bob Drake
 Inspector: _____

ATL-LOG1 LL CD4827 POWER ENGINEERS - SAG HARBOR.GPJ ATL4-08.GDT 12/22/20

ATLANTIC TESTING LABORATORIES, Limited

Subsurface Investigation

Boring No.: BH-1

Report No.: CD4827E-01-12-20

Sheet 2 of 4

DEPTH	METHOD OF ADVANCE	SAMPLE NO.	DEPTH OF SAMPLE		SAMPLE TYPE	BLOWS ON SAMPLER PER 6" 2" O.D. SAMPLER	DEPTH OF CHANGE	CLASSIFICATION OF MATERIAL	RECOVERY (inches)
			From	To					
26								non-plastic)	
27							27.0		
28									
29		10	29.0	31.0	SS	WH 4 5 6		Black SILT; some f SAND (moist, non-plastic)	20
30									
31									
32									
33									
34		11	34.0	36.0	SS	1 5 7 12		Black SILT; some mf+ SAND (moist, non-plastic) w = 35.2%	24
35									
36									
37									
38									
39		12	39.0	41.0	SS	5 5 5 10		Black SILT; some f SAND (moist, non-plastic)	20
40									
41									
42									
43									
44		13	44.0	46.0	SS	4 8 12 10		Black and Brown cf SAND; some SILT; trace f GRAVEL (moist, non-plastic)	24
45									
46							47.0		
47									
48									
49		14	49.0	51.0	SS	10 13 21 19		Light Brown cmf SAND; trace SILT (moist, non-plastic)	18
50									
51							52.0		
52									
53								Encountered COBBLE fragments from 54.0 to 86.0 feet.	
54		15	54.0	56.0	SS	3 2 11 17		Reddish-Brown cmf SAND; some CLAY; little SILT; trace mf GRAVEL (moist, moderately plastic) w = 20.5% PL = 20, LL = 42, PI = 22	18
55									
56							57.0		
57								Encountered COBBLE from 57.0 to 57.7 feet.	
58									
59		16	59.0	60.4	SS	46 52 50/5"		Light Brown cmf SAND; some mf GRAVEL; trace SILT (moist, non-plastic)	10
60									
61									
62									

ATL-LOG1 LL CD4827 POWER ENGINEERS - SAG HARBOR.GPJ ATL4-08.GDT 12/22/20

ATLANTIC TESTING LABORATORIES, Limited

Subsurface Investigation

Boring No.: BH-1

Report No.: CD4827E-01-12-20

Sheet 3 of 4

DEPTH	METHOD OF ADVANCE	SAMPLE NO.	DEPTH OF SAMPLE		SAMPLE TYPE	BLOWS ON SAMPLER PER 6" 2" O.D. SAMPLER	DEPTH OF CHANGE	CLASSIFICATION OF MATERIAL	RECOVERY (inches)
			From	To					
63									
64		17	64.0	64.4	SS	50/5"		Rust Orange mf GRAVEL; trace cmf SAND; trace SILT (moist, non-plastic)	2
65									
66									
67							67.0		
68									
69		18	69.0	69.9	SS	38 50/5"		White mf GRAVEL; little cmf SAND; trace SILT (moist, non-plastic)	2
70								Encountered COBBLE from 70.0 to 70.8 feet.	
71									
72									
73									
74		19	74.0	76.0	SS	51 44 42 61		Greyish-White cmf SAND; trace f GRAVEL; trace SILT (moist, non-plastic) w = 13.2%	24
75									
76									
77									
78								Advanced casing to 79.0 feet and began advancing 3 7/8" tri-cone roller bit wet rotary open hole within the borehole.	
79	WET ROTARY	20	79.0	79.7	SS	37 50/3"		Greyish-White cmf SAND; and mf GRAVEL; trace SILT (moist, non-plastic)	2
80									
81									
82							82.0		
83									
84		21	84.0	85.9	SS	27 41 55 50/5"		Reddish-Brown cmf SAND; some CLAY; little SILT; trace f GRAVEL (moist, moderately plastic)	8
85									
86									
87							87.0		
88									
89		22	89.0	90.4	SS	28 49 50/5"		Light Brown cmf SAND; trace f GRAVEL; trace SILT (moist, non-plastic)	2
90									
91									
92									
93									
94		23	94.0	95.3	SS	23 42 50/4"		Light Brown mf SAND; trace SILT (moist, non-plastic)	4
95									
96									
97									
98									
99		24	99.0	101.0	SS	23 26 41 54		Light Brown SILT; some cmf+ SAND (moist, non-plastic)	10
100									

ATL-LOG1 LL CD4827 POWER ENGINEERS - SAG HARBOR.GPJ ATL4-08.GDT 12/22/20

ATLANTIC TESTING LABORATORIES, Limited

Subsurface Investigation

Boring No.: BH-1

Report No.: CD4827E-01-12-20

Sheet 4 of 4

DEPTH	METHOD OF ADVANCE	SAMPLE NO.	DEPTH OF SAMPLE		SAMPLE TYPE	BLOWS ON SAMPLER PER 6" 2" O.D. SAMPLER	DEPTH OF CHANGE	CLASSIFICATION OF MATERIAL	RECOVERY (inches)
			From	To					
101							101.0	w = 22.9%	
102								Boring terminated at 101.0 feet.	
103								Notes:	
104								1. Borehole backfilled with on-site soils.	
105								2. A brass-lined 3" split spoon sampler was utilized to obtain samples S-8, S-19 and S-24. All other samples were collected with a 2" split spoon sampler.	
106								3. Bulk sample BS-1 was collected from auger cuttings at a depth of 10.0 feet.	
107									
108									
109									
110									
111									
112									
113									
114									
115									
116									
117									
118									
119									
120									
121									
122									
123									
124									
125									
126									
127									
128									
129									
130									
131									
132									
133									
134									
135									
136									
137									

ATL-LOG1 LL CD4827 POWER ENGINEERS - SAG HARBOR.GPJ ATL4-08.GDT 12/22/20

ATLANTIC TESTING LABORATORIES, Limited

Subsurface Investigation

Client: Power Engineers

Project: Subsurface Investigation

PSEG - L1 Bridgehampton 9R to Buell 9E Substations

Sag Harbor, New York

Report No.: CD4827E-01-12-20

Boring Location: See Boring Location Plan

Boring No.: BH-2 Sheet 1 of 4

Coordinates

Latitude _____

Longitude _____

Sampler Hammer

Weight: 140 lbs.

Fall: 30 in.

Hammer Type: Automatic

Ground Elev.: _____ Boring Advance By:

HW (4") Casing/3 7/8" Wet Rotary

Start Date: 9/23/2020 Finish Date: 9/24/2020

Groundwater Observations			
Date	Time	Depth	Casing
<u>9/23/2020</u>	<u>AM</u>	<u>*9.7'</u>	<u>9.0'</u>
<u>9/23/2020</u>	<u>PM</u>	<u>*11.1'</u>	<u>14.0'</u>
<u>9/24/2020</u>	<u>AM</u>	<u>*22.4'</u>	<u>14.0'</u>
<u>9/24/2020</u>	<u>PM</u>	<u>*22.9</u>	<u>14.0'</u>
<u>9/24/2020</u>	<u>PM</u>	<u>*22.8'</u>	<u>CAVED</u>

Borehole caved at 101.6 feet. *May be affected by

water utilized to advance the borehole.

DEPTH	METHOD OF ADVANCE	SAMPLE NO.	DEPTH OF SAMPLE		SAMPLE TYPE	BLOWS ON SAMPLER PER 6" 2" O.D. SAMPLER	DEPTH OF CHANGE	CLASSIFICATION OF MATERIAL	Recovery (Inches)
			From	To					
1	C								
2	A								
3	S	1	3.0	5.0	SS	5 6 7 6		Hand cleared to 3.0 feet and began sampling.	
4	I							Orange cmf SAND; little mf GRAVEL; little SILT (wet, non-plastic)	8
5	N	2	5.0	7.0	SS	4 4 3 7		Orange cmf SAND; little SILT; trace f GRAVEL (wet, non-plastic)	7
6									
7	G	3	7.0	9.0	SS	4 5 7 5		Orangish-Brown cmf SAND; little SILT; trace f GRAVEL (wet, non-plastic)	6
8							9.0		
9		4	9.0	11.0	SS	5 7 9 8		Brown cmf SAND; some cmf GRAVEL; little SILT (saturated, non-plastic)	9
10									
11		5	11.0	13.0	SS	6 9 10 11		Brown cmf SAND; and mf GRAVEL; trace SILT (saturated, non-plastic) w = 7.4%	13
12									
13		6	13.0	15.0	SS	5 7 6 7		Brown cmf SAND; little cmf GRAVEL; little SILT (wet, non-plastic)	9
14									
15	W								
16	E								
17	T							Advanced casing to 14.0 feet and began advancing 3 7/8" tri-cone roller bit wet rotary open hole within the borehole.	
18	R								
19	O								
20	T	7	19.0	21.0	SS	5 5 9 9		Brown cmf SAND; little SILT; trace c GRAVEL (wet, non-plastic)	5
21	A							COBBLE fragments in split spoon shoe	
22	R						22.0		
23									
24									
25		8	24.0	26.0	SS	10 10 20 16		Brown cmf SAND; little SILT; trace f GRAVEL; trace CLAY (wet,	7

SS Split Spoon Sample

NX Rock Core

SH Undisturbed Sample (Shelby Tube)

Estimated Groundwater

Drillers: Scott McGregor; Bob Drake

Inspector: _____

ATL-LOG1 LL CD4827 POWER ENGINEERS - SAG HARBOR.GPJ ATL4-08.GDT 12/22/20

ATLANTIC TESTING LABORATORIES, Limited

Subsurface Investigation

Boring No.: BH-2

Report No.: CD4827E-01-12-20

Sheet 2 of 4

DEPTH	METHOD OF ADVANCE	SAMPLE NO.	DEPTH OF SAMPLE		SAMPLE TYPE	BLOWS ON SAMPLER PER 6" 2" O.D. SAMPLER	DEPTH OF CHANGE	CLASSIFICATION OF MATERIAL	RECOVERY (inches)
			From	To					
26								very slightly plastic)	
27									
28									
29		9	29.0	31.0	SS	7 8 12 9		Brown c-mf+ SAND; little SILT; trace mf GRAVEL (wet, non-plastic) w = 12.1% LL = NP, PL = NP, PI = NP	8
30									
31									
32							32.0		
33									
34		10	34.0	36.0	SS	9 9 10 12		Light Brown cmf SAND; little SILT (saturated, non-plastic)	7
35									
36									
37									
38									
39		11	39.0	41.0	SS	11 8 11 14		Light Brown cmf SAND; some mf GRAVEL; little SILT (saturated, non-plastic)	9
40									
41									
42									
43									
44		12	44.0	46.0	SS	8 7 7 12		Brown mf SAND; trace SILT (wet, non-plastic)	14
45									
46									
47									
48		13	48.0	50.0	SS	7 12 16 13		Brown cmf SAND; trace SILT (saturated, non-plastic)	8
49									
50		14	50.0	52.0	SS	14 24 29 28		Brown cmf SAND; trace SILT (saturated, non-plastic)	18
51									
52									
53									
54		15	54.0	56.0	SS	8 10 12 14		Light Brown cmf SAND; trace SILT (saturated, non-plastic)	10
55									
56									
57									
58									
59		16	59.0	61.0	SS	12 11 14 19		Light Brown cmf SAND; some f GRAVEL; little SILT (saturated, non-plastic)	17
60									
61									
62									

ATL-LOG1 LL CD4827 POWER ENGINEERS - SAG HARBOR.GPJ ATL4-08.GDT 12/22/20

ATLANTIC TESTING LABORATORIES, Limited

Subsurface Investigation

Boring No.: BH-2

Report No.: CD4827E-01-12-20

Sheet 3 of 4

DEPTH	METHOD OF ADVANCE	SAMPLE NO.	DEPTH OF SAMPLE		SAMPLE TYPE	BLOWS ON SAMPLER PER 6" 2" O.D. SAMPLER	DEPTH OF CHANGE	CLASSIFICATION OF MATERIAL	RECOVERY (inches)
			From	To					
63									
64		17	64.0	66.0	SS	13 12 18 18		Light Brown cmf SAND; little SILT (saturated, non-plastic)	
65									
66									
67									
68									
69		18	69.0	71.0	SS	15 15 21 18		Brown cmf SAND; little mf GRAVEL; little SILT (saturated, non-plastic)	3
70									
71									
72									
73									
74		19	74.0	76.0	SS	12 7 8 9		Light Brown c-mf+ SAND; trace SILT (saturated, non-plastic) w = 25.5%	6
75									
76									
77									
78									
79		20	79.0	81.0	SS	9 11 10 9		Light Brown cmf SAND; some mf GRAVEL; little SILT (saturated, non-plastic)	5
80									
81									
82							82.0		
83									
84		21	84.0	86.0	SS	15 17 18 20		Brown cmf SAND; little SILT; trace mf GRAVEL (wet, non-plastic)	10
85									
86									
87									
88									
89		22	89.0	91.0	SS	21 21 23 27		Brown c-mf+ SAND; little c+f GRAVEL; trace CLAY; trace SILT (wet, very slightly plastic) w = 13.8%	16
90									
91									
92									
93									
94		23	94.0	96.0	SS	22 24 24 25		Light Brown cmf SAND; trace SILT (wet, non-plastic)	20
95									
96									
97									
98		24	98.0	100.0	SS	24 27 22 28		Brown cmf SAND; little SILT; little c+f GRAVEL (wet, non-plastic)	24
99									
100									

ATL-LOG1 LL CD4827 POWER ENGINEERS - SAG HARBOR.GPJ ATL4-08.GDT 12/22/20

ATLANTIC TESTING LABORATORIES, Limited

Subsurface Investigation

Boring No.: BH-2

Report No.: CD4827E-01-12-20

Sheet 4 of 4

DEPTH	METHOD OF ADVANCE	SAMPLE NO.	DEPTH OF SAMPLE		SAMPLE TYPE	BLOWS ON SAMPLER PER 6" 2" O.D. SAMPLER	DEPTH OF CHANGE	CLASSIFICATION OF MATERIAL	RECOVERY (inches)
			From	To					
101		25	100.0	102.0	SS	34 48 54 57		Brown cmf SAND; little SILT; little c+f GRAVEL (wet, non-plastic)	24
102							102.0		
103									
104									
105									
106									
107									
108									
109									
110									
111									
112									
113									
114									
115									
116									
117									
118									
119									
120									
121									
122									
123									
124									
125									
126									
127									
128									
129									
130									
131									
132									
133									
134									
135									
136									
137									

Boring terminated at 102.0 feet.

Notes:

1. Borehole backfilled with on-site soils.
2. A brass-lined 3" split spoon sampler was utilized to obtain samples S-14 and S-25. All other samples were collected with a 2" split spoon sampler.
3. Bulk sample BS-1 was collected from auger cuttings at a depth of 5.0 feet.

ATL-LOG1 LL CD4827 POWER ENGINEERS - SAG HARBOR.GPJ ATL4-08.GDT 12/22/20

ATLANTIC TESTING LABORATORIES, Limited

Subsurface Investigation

Client: Power Engineers
 Project: Subsurface Investigation
PSEG - L1 Bridgehampton 9R to Buell 9E Substations
Sag Harbor, New York

Report No.: CD4827E-01-12-20
 Boring Location: See Boring Location Plan

Boring No.: BH-3 Sheet 1 of 4

Coordinates _____
 Latitude _____
 Longitude _____
 Sampler Hammer
 Weight: 140 lbs.
 Fall: 30 in.
 Hammer Type: Automatic
 Ground Elev.: _____ Boring Advance By: _____

Start Date: 9/22/2020 Finish Date: 9/23/2020

Date	Time	Depth	Casing
9/22/2020	AM	*10.0'	4.0'
9/22/2020	AM	*18.5'	9.0'
9/22/2020	PM	*18.6'	19.0'
9/23/2020	AM	*18.1'	19.0'
9/23/2020	AM	*19.4'	19.0'

HW (4") Casing/3 7/8" Wet Rotary

[Diagram showing casing and sampler details]

DEPTH	METHOD OF ADVANCE	SAMPLE NO.	DEPTH OF SAMPLE		SAMPLE TYPE	BLOWS ON SAMPLER PER 6" 2" O.D. SAMPLER	DEPTH OF CHANGE	CLASSIFICATION OF MATERIAL	Recovery (Inches)
			From	To					
1	C							Hand cleared to 3.0 feet and began sampling.	
2	A								
3	S								
4	I	1	3.0	5.0	SS	7 9 10 7		Light Brown cmf SAND; trace f GRAVEL; trace SILT; trace ORGANIC MATERIAL (leaf) (moist, non-plastic)	17
5	N							Light Brown cmf SAND; trace SILT (moist, non-plastic)	
6	G	2	5.0	7.0	SS	8 11 9 10			15
7								Light Brown cmf SAND; little mf GRAVEL; trace SILT (moist, non-plastic)	
8		3	7.0	9.0	SS	6 6 7 13			16
9								Brown cmf SAND; little SILT; trace f GRAVEL (wet, non-plastic)	
10		4	9.0	11.0	SS	8 7 8 10			11
11								Light Brown c-mf SAND; some mf+ GRAVEL; trace SILT (wet, non-plastic) w = 9.8%	
12		5	11.0	13.0	SS	9 12 13 13			12
13							13.0	Brown cmf SAND; little SILT; trace f GRAVEL (wet, non-plastic)	
14		6	13.0	15.0	SS	5 5 6 6			10
15								Advanced casing to 19.0 feet and began advancing 3 7/8" tri-cone roller bit wet rotary open hole within the borehole.	
16									
17									
18								Brown cmf SAND; trace mf GRAVEL; trace SILT (saturated, non-plastic)	
19		7	18.0	20.0	SS	4 4 6 8			10
20	WET							Encountered loss of drilling water return at 18.7 feet. Brown cmf SAND; trace m GRAVEL; trace SILT (saturated, non-plastic)	
21	R	8	20.0	22.0	SS	17 19 19 18			10
22	O							Regained drilling water return at 23.6 feet.	
23	T								
24	A						23.0	Light Brown cmf SAND; little SILT; trace f GRAVEL (saturated,	
25	R								
26	Y								
27									
28									
29									
30									
31									
32									
33									
34									
35									
36									
37									
38									
39									
40									
41									
42									
43									
44									
45									
46									
47									
48									
49									
50									
51									
52									
53									
54									
55									
56									
57									
58									
59									
60									
61									
62									
63									
64									
65									
66									
67									
68									
69									
70									
71									
72									
73									
74									
75									
76									
77									
78									
79									
80									
81									
82									
83									
84									
85									
86									
87									
88									
89									
90									
91									
92									
93									
94									
95									
96									
97									
98									
99									
100									

SS Split Spoon Sample
 NX Rock Core
 SH Undisturbed Sample (Shelby Tube)
 Estimated Groundwater

Drillers: Scott McGregor; Bob Drake
 Inspector: _____

ATL-LOG1 LL CD4827 POWER ENGINEERS - SAG HARBOR.GPJ ATL4-08.GDT 12/22/20

ATLANTIC TESTING LABORATORIES, Limited

Subsurface Investigation

Boring No.: BH-3

Report No.: CD4827E-01-12-20

Sheet 2 of 4

DEPTH	METHOD OF ADVANCE	SAMPLE NO.	DEPTH OF SAMPLE		SAMPLE TYPE	BLOWS ON SAMPLER PER 6" 2" O.D. SAMPLER	DEPTH OF CHANGE	CLASSIFICATION OF MATERIAL	RECOVERY (inches)
			From	To					
26								non-plastic)	
27							27.0		
28									
29		10	29.0	31.0	SS	3 4 4 6		Brown cmf SAND; little SILT (wet, non-plastic)	13
30									
31									
32									
33									
34		11	34.0	36.0	SS	3 4 7 6		Light Brown c-m+f SAND; trace SILT; trace f GRAVEL (wet, non-plastic) w = 16.5%	10
35									
36									
37									
38									
39		12	39.0	41.0	SS	4 6 7 9		Light Brown cmf SAND; little SILT (wet, non-plastic)	12
40									
41									
42							42.0		
43									
44		13	44.0	46.0	SS	6 8 10 11		Greyish-Brown mf SAND; some SILT; trace CLAY (wet, very plastic)	16
45									
46									
47									
48									
49		14	49.0	51.0	SS	8 6 9 12		Brown mf SAND; and SILT; trace CLAY (saturated, non-plastic)	15
50									
51									
52									
53									
54		15	54.0	56.0	SS	9 8 11 10		Brown c-mf+ SAND; and SILT (saturated, non-plastic) w = 21.6% LL = NP, PL = NP, PI = NP	12
55									
56									
57							57.0		
58									
59		16	59.0	61.0	SS	8 13 17 13		Light Brown mf SAND; little SILT (wet, non-plastic)	15
60									
61									
62									

ATL-LOG1 LL CD4827 POWER ENGINEERS - SAG HARBOR.GPJ ATL4-08.GDT 12/22/20

ATLANTIC TESTING LABORATORIES, Limited

Subsurface Investigation

Boring No.: BH-3

Report No.: CD4827E-01-12-20

Sheet 3 of 4

DEPTH	METHOD OF ADVANCE	SAMPLE NO.	DEPTH OF SAMPLE		SAMPLE TYPE	BLOWS ON SAMPLER PER 6" 2" O.D. SAMPLER	DEPTH OF CHANGE	CLASSIFICATION OF MATERIAL	RECOVERY (inches)
			From	To					
63									
64		17	64.0	66.0	SS	9 11 15 14		Brown cmf SAND; little SILT; trace CLAY (wet, very slightly plastic)	13
65									
66									
67									
68									
69		18	69.0	71.0	SS	10 10 18 20		Brown mf SAND; little SILT (wet, non-plastic)	15
70									
71									
72									
73		19	73.0	75.0	SS	11 10 15 14		Light Brown mf SAND; little SILT (wet, non-plastic)	12
74									
75		20	75.0	77.0	SS	21 27 35 36		Light Brown mf SAND; little SILT (wet, non-plastic)	24
76									
77									
78							78.0		
79		21	79.0	81.0	SS	12 17 24 24		Greyish-Brown cmf SAND; little SILT; little CLAY (wet, slightly plastic)	5
80									
81									
82									
83									
84		22	84.0	86.0	SS	10 15 22 23		Greyish-Brown c-mf+ SAND; little SILT; little CLAY; little mf GRAVEL (saturated, slightly plastic) w = 19.2%	13
85									
86									
87									
88									
89		23	89.0	91.0	SS	11 16 26 24		Light Brown mf SAND; little SILT; trace CLAY (wet, very slightly plastic)	16
90									
91									
92									
93									
94		24	94.0	96.0	SS	12 10 14 15		Greyish-Brown cmf SAND; and cmf GRAVEL; little SILT; trace CLAY (saturated, very slightly plastic)	3
95									
96									
97									
98									
99		25	99.0	101.0	SS	15 11 12 12		Greyish-Brown cmf SAND; little SILT; trace f GRAVEL (saturated,	4
100									

ATL-LOG1 LL CD4827 POWER ENGINEERS - SAG HARBOR.GPJ ATL4-08.GDT 12/22/20

ATLANTIC TESTING LABORATORIES, Limited

Subsurface Investigation

Boring No.: **BH-3**

Report No.: **CD4827E-01-12-20**

Sheet **4** of **4**

DEPTH	METHOD OF ADVANCE	SAMPLE NO.	DEPTH OF SAMPLE		SAMPLE TYPE	BLOWS ON SAMPLER PER 6" 2" O.D. SAMPLER	DEPTH OF CHANGE	CLASSIFICATION OF MATERIAL	RECOVERY (inches)
			From	To					
101							101.0	non-plastic)	
102									
103									
104									
105									
106									
107									
108									
109									
110									
111									
112									
113									
114									
115									
116									
117									
118									
119									
120									
121									
122									
123									
124									
125									
126									
127									
128									
129									
130									
131									
132									
133									
134									
135									
136									
137									

f - fine
m - medium
c - coarse

and - 35-50%
some - 20-35%
little - 10-20%
trace - 0-10%

Boring terminated at 101.0 feet.

Notes:
1. Borehole backfilled with on-site soils.
2. A brass-lined 3" split spoon sampler was utilized to obtain samples S-8 and S-20. All other samples were collected with a 2" split spoon sampler.
3. Bulk sample BS-1 was collected from auger cuttings at a depth of 10.0 feet.

ATL-LOG1 LL CD4827 POWER ENGINEERS - SAG HARBOR.GPJ ATL4-08.GDT 12/22/20

ATLANTIC TESTING LABORATORIES, Limited

Subsurface Investigation

Client: Power Engineers
 Project: Subsurface Investigation
PSEG - L1 Bridgehampton 9R to Buell 9E Substations
Sag Harbor, New York

Report No.: CD4827E-01-12-20
 Boring Location: See Boring Location Plan

Boring No.: BH-4 Sheet 1 of 1

Start Date: 5/19/2020 Finish Date: 5/19/2020

Coordinates
 Latitude _____
 Longitude _____

Sampler Hammer
 Weight: 140 lbs.
 Fall: 30 in.
 Hammer Type: Automatic

Groundwater Observations
 Date Time Depth Casing

Ground Elev.: _____ Boring Advance By: 4 1/4" Auger

Based on the driller's observation, subsurface water was not encountered during borehole advancement.

DEPTH	METHOD OF ADVANCE	SAMPLE NO.	DEPTH OF SAMPLE		SAMPLE TYPE	BLOWS ON SAMPLER PER 6" 2" O.D. SAMPLER	DEPTH OF CHANGE	CLASSIFICATION OF MATERIAL	Recovery (Inches)
			From	To					
1	ROTTING	1	0.0	2.0	SS	2 4 4 6	4.0	Brown cmf SAND; trace f GRAVEL; trace SILT; trace ORGANIC MATERIAL (roots, wood fragments) (moist, non-plastic)	20
2		2	2.0	4.0	SS	3 3 5 8		Encountered COBBLE fragments from surface to boring termination.	10
3								Brownish-Orange cmf SAND; trace f GRAVEL; trace SILT; trace ORGANIC MATERIAL (wood fragments) (moist, non-plastic)	12
4		3	4.0	6.0	SS	2 3 2 4		Light Brown cmf SAND; trace f GRAVEL; trace SILT (moist, non-plastic)	6
5							16.0	Light Brown cmf SAND; little c+f GRAVEL; trace SILT (moist, non-plastic)	18
6		4	6.0	8.0	SS	4 5 6 9		Light Brown cmf SAND; some c+mf GRAVEL; trace SILT (moist, non-plastic)	10
7								Light Brown cmf SAND; trace f GRAVEL; trace SILT (moist, non-plastic) w = 5.3%	20
8		5	8.0	10.0	SS	9 8 6 6		Light Brown cmf SAND; trace f GRAVEL; trace SILT (moist, non-plastic)	18
9								Light Brown cmf SAND; little c+f GRAVEL; trace SILT (moist, non-plastic)	
10		6	10.0	12.0	SS	6 5 6 8			
11									
12		7	12.0	14.0	SS	9 8 6 6			
13									
14		8	14.0	16.0	SS	5 7 11 10			
15									
16									
17									
18									
19									
20									
21									
22									
23									
24									
25									

SS Split Spoon Sample
 NX Rock Core
 SH Undisturbed Sample (Shelby Tube)
 Estimated Groundwater

Drillers: Scott McGregor: Bob Drake
 Inspector: _____

ATL-LOG1 LL CD4827 POWER ENGINEERS - SAG HARBOR.GPJ ATL4-08.GDT 12/22/20

ATLANTIC TESTING LABORATORIES, Limited

Subsurface Investigation

Client: Power Engineers

Project: Subsurface Investigation
PSEG - L1 Bridgehampton 9R to Buell 9E Substations
Sag Harbor, New York

Report No.: CD4827E-01-12-20

Boring Location: See Boring Location Plan
Offset from original boring location 2.0' East due to
proximity to the road and 1.0' West due to trees.

Start Date: 5/14/2020 Finish Date: 5/14/2020

Boring No.: BH-5 Sheet 1 of 1

Coordinates
Latitude _____
Longitude _____

Sampler Hammer
Weight: 140 lbs.
Fall: 30 in.
Hammer Type: Automatic

Ground Elev.: _____ Boring Advance By: 4 1/4" Auger

Groundwater Observations

Date	Time	Depth	Casing

Based on the driller's observation, subsurface water
was not encountered during borehole advancement.

DEPTH	METHOD OF ADVANCE	SAMPLE NO.	DEPTH OF SAMPLE		SAMPLE TYPE	BLOWS ON SAMPLER PER 6" 2" O.D. SAMPLER	DEPTH OF CHANGE	CLASSIFICATION OF MATERIAL	Recovery (Inches)
			From	To					
1	ROCKET	1	0.0	2.0	SS	1 1 1 2	8.0	Light Brownish-Yellow mf SAND; trace SILT (moist, non-plastic)	14
2		2	2.0	4.0	SS	2 2 2 4		Light Brownish-Yellow mf SAND; trace mf GRAVEL; trace SILT (moist, non-plastic) COBBLE Fragments	11
3									
4		3	4.0	6.0	SS	2 3 3 4		Light Brownish-Yellow mf SAND; trace f GRAVEL; trace SILT (moist, non-plastic)	20
5									
6		4	6.0	8.0	SS	3 4 3 3		Light Brownish-Yellow mf SAND; trace f GRAVEL; trace SILT; trace ORGANIC MATERIAL (wood fragments) (moist, non-plastic)	16
7									
8		5	8.0	10.0	SS	3 4 6 8		Light Brownish-Yellow mf SAND; trace SILT (moist, non-plastic)	18
9							16.0		
10		6	10.0	12.0	SS	8 7 9 8		Light Brownish-Yellow mf SAND; trace SILT (moist, non-plastic)	16
11									
12		7	12.0	14.0	SS	3 5 6 7		Light Brownish-Yellow f SAND; trace SILT (moist, non-plastic)	20
13									
14		8	14.0	16.0	SS	5 7 10 11		Light Brown f SAND; trace mf GRAVEL; trace SILT (moist, non-plastic)	20
15									
16								Boring terminated at 16.0 feet.	
17									
18								Notes:	
19								1. Borehole backfilled with on-site soils.	
20								2. Bulk samples BS-1 and BS-2 were collected from auger cuttings at depths of 5.0 and 10.0 feet, respectively.	
21									
22									
23									
24									
25									

SS Split Spoon Sample
NX Rock Core
SH Undisturbed Sample (Shelby Tube)
Estimated Groundwater

Drillers: Scott McGregor: Bob Drake

Inspector: _____

ATL-LOG1 LL CD4827 POWER ENGINEERS - SAG HARBOR.GPJ ATL4-08.GDT 12/22/20

Subsurface Investigation

Based on the driller's observation, subsurface water
was not encountered during borehole advancement.

ATL-LOG1LL CD4827 POWER ENGINEERS - SAG HARBOR.GPJ ATL4-08.GDT 12/22/20

Drillers: Scott McGregor: Bob Drake

Inspector: _____

ATLANTIC TESTING LABORATORIES, Limited

Subsurface Investigation

Client: Power Engineers
 Project: Subsurface Investigation
PSEG - L1 Bridgehampton 9R to Buell 9E Substations
Sag Harbor, New York

Report No.: CD4827E-01-12-20
 Boring Location: See Boring Location Plan

Boring No.: BH-7 Sheet 1 of 1

Start Date: 5/19/2020 Finish Date: 5/19/2020

Coordinates
 Latitude _____
 Longitude _____

Sampler Hammer
 Weight: 140 lbs.
 Fall: 30 in.
 Hammer Type: Automatic

Groundwater Observations
 Date Time Depth Casing

Ground Elev.: _____ Boring Advance By: 4 1/4" Auger

Based on the driller's observation, subsurface water was not encountered during borehole advancement.

DEPTH	METHOD OF ADVANCE	SAMPLE NO.	DEPTH OF SAMPLE		SAMPLE TYPE	BLOWS ON SAMPLER PER 6" 2" O.D. SAMPLER				DEPTH OF CHANGE	CLASSIFICATION OF MATERIAL	Recovery (Inches)
			From	To								
1	A	1	0.0	2.0	SS	1	1	2	3	6.0	Light Brownish-Orange cmf SAND; trace f GRAVEL; trace SILT (moist, non-plastic)	16
2	B	2	2.0	4.0	SS	2	3	6	8		Light Brown cmf SAND; trace mf GRAVEL; trace SILT (moist, non-plastic) COBBLE Fragments	12
3												
4		3	4.0	6.0	SS	1	2	4	6		Light Brown cmf SAND; trace mf GRAVEL; trace SILT (moist, non-plastic)	14
5										16.0	Light Brown cmf SAND; little mf GRAVEL; trace SILT (moist, non-plastic)	12
6		4	6.0	8.0	SS	7	6	10	13		Light Brown cmf SAND; little cmf GRAVEL; trace SILT (moist, non-plastic) COBBLE Fragments	16
7												
8		5	8.0	10.0	SS	3	5	5	6		Light Brown cmf SAND; little mf GRAVEL; trace SILT (moist, non-plastic) COBBLE Fragments	6
9												
10		6	10.0	12.0	SS	5	11	24	22		Light Brownish-Orange cmf SAND; little mf GRAVEL; trace SILT (moist, non-plastic) COBBLE Fragments	14
11												
12		7	12.0	14.0	SS	9	9	7	9		Light Brown cmf SAND; trace f GRAVEL; trace SILT (moist, non-plastic)	16
13												
14		8	14.0	16.0	SS	13	20	17	18		Boring terminated at 16.0 feet.	
15												
16												
17												
18												
19												
20												
21												
22												
23												
24												
25												

SS Split Spoon Sample
 NX Rock Core
 SH Undisturbed Sample (Shelby Tube)
 Estimated Groundwater

Drillers: Scott McGregor: Bob Drake
 Inspector: _____

ATL-LOG1 LL CD4827 POWER ENGINEERS - SAG HARBOR.GPJ ATL4-08.GDT 12/22/20

ATLANTIC TESTING LABORATORIES, Limited

Subsurface Investigation

Client: Power Engineers
 Project: Subsurface Investigation
PSEG - L1 Bridgehampton 9R to Buell 9E Substations
Sag Harbor, New York

Report No.: CD4827E-01-12-20
 Boring Location: See Boring Location Plan

Boring No.: BH-8 Sheet 1 of 2

Coordinates
 Latitude _____
 Longitude _____

Sampler Hammer
 Weight: 140 lbs.
 Fall: 30 in.
 Hammer Type: Automatic

Ground Elev.: _____ Boring Advance By: _____
3.75" Casing

Start Date: 5/19/2020 Finish Date: 5/19/2020

Groundwater Observations			
Date	Time	Depth	Casing
<u>5/19/2020</u>	<u>PM</u>	<u>DRY</u>	<u>39.0'</u>
<u>5/19/2020</u>	<u>PM</u>	<u>DRY</u>	<u>CAVED</u>
_____	_____	_____	_____
_____	_____	_____	_____

Borehole caved at 34.3 feet.

DEPTH	METHOD OF ADVANCE	SAMPLE NO.	DEPTH OF SAMPLE		SAMPLE TYPE	BLOWS ON SAMPLER PER 6" 2" O.D. SAMPLER	DEPTH OF CHANGE	CLASSIFICATION OF MATERIAL	Recovery (Inches)
			From	To					
1	C A S I N G	1	0.0	2.0	SS	WH 1 1/12"	0.3	4" TOPSOIL & ORGANIC MATERIAL Light Brown mf SAND; trace SILT; trace ORGANIC MATERIAL (wood fragments) (moist, non-plastic) Light Brown f SAND; little SILT (moist, non-plastic) Light Brown f SAND; little SILT; trace ORGANIC MATERIAL (wood fragments) (moist, non-plastic)	8
2		2	2.0	4.0	SS	1 1 2 3			18
3									
4		3	4.0	6.0	SS	2 3 5 6			10
5							6.0	Greyish-Brown mf SAND; little SILT; trace mf GRAVEL (moist, non-plastic)	19
6		4	6.0	8.0	SS	5 6 8 11			
7							8.0	Light Brown cmf SAND; some mf GRAVEL; trace SILT (moist, non-plastic) w = 4.4% Encountered COBBLE fragments from 6.0 feet to boring termination. Light Brown cmf SAND; trace f GRAVEL; trace SILT (moist, non-plastic) Light Brown cmf SAND; trace f GRAVEL; trace SILT; trace ORGANIC MATERIAL (wood fragments) (moist, non-plastic) Light Brown cmf SAND; little mf GRAVEL; trace SILT (moist, non-plastic) Light Brown cmf SAND; trace f GRAVEL; trace SILT (moist, non-plastic)	10
8		5	8.0	10.0	SS	3 8 11 11			16
9									
10		6	10.0	12.0	SS	8 9 12 13			15
11									
12		7	12.0	14.0	SS	4 4 7 6			12
13									
14		8	14.0	16.0	SS	4 6 6 9			
15									
16									
17									
18									
19		9	19.0	21.0	SS	14 33 16 15			22
20									
21									
22									
23									
24		10	24.0	26.0	SS	7 4 13 9		Light Brown cmf SAND; little mf GRAVEL; trace SILT (moist,	14
25									

SS Split Spoon Sample
 NX Rock Core
 SH Undisturbed Sample (Shelby Tube)
 Estimated Groundwater

Drillers: Scott McGregor: Bob Drake
 Inspector: _____

ATL-LOG1 LL CD4827 POWER ENGINEERS - SAG HARBOR.GPJ ATL4-08.GDT 12/22/20

ATLANTIC TESTING LABORATORIES, Limited

Subsurface Investigation

Boring No.: BH-8

Report No.: CD4827E-01-12-20

Sheet 2 of 2

DEPTH	METHOD OF ADVANCE	SAMPLE NO.	DEPTH OF SAMPLE		SAMPLE TYPE	BLOWS ON SAMPLER PER 6" 2" O.D. SAMPLER	DEPTH OF CHANGE	CLASSIFICATION OF MATERIAL	RECOVERY (inches)
			From	To					
26								non-plastic)	
27									
28									
29		11	29.0	31.0	SS	6 6 7 8		Light Brownish-Orange cmf SAND; trace f GRAVEL; trace SILT (moist, non-plastic)	14
30									
31									
32									
33									
34		12	34.0	36.0	SS	7 8 8 11		Light Brown cmf SAND; trace f GRAVEL; trace SILT (moist, non-plastic)	17
35									
36									
37									
38									
39		13	39.0	41.0	SS	6 4 19 11		Light Brown cmf SAND; some c+f GRAVEL; trace SILT (moist, non-plastic)	8
40							41.0		
41								Boring terminated at 41.0 feet.	
42									
43								Notes:	
44								1. Borehole backfilled with on-site soils.	
45								2. A brass-lined 3" split spoon sampler was utilized to obtain sample S-9. All other samples were collected with a 2" split spoon sampler.	
46								2. Bulk sample BS-1 was collected from auger cuttings at a depth of 10.0 feet.	
47									
48									
49									
50									
51									
52									
53									
54									
55									
56									
57									
58									
59									
60									
61									
62									

ATL-LOG1 LL CD4827 POWER ENGINEERS - SAG HARBOR.GPJ ATL4-08.GDT 12/22/20

ATLANTIC TESTING LABORATORIES, Limited

Subsurface Investigation

Client: Power Engineers
 Project: Subsurface Investigation
PSEG - L1 Bridgehampton 9R to Buell 9E Substations
Sag Harbor, New York

Report No.: CD4827E-01-12-20
 Boring Location: See Boring Location Plan

Boring No.: BH-9 Sheet 1 of 2

Coordinates
 Latitude _____
 Longitude _____

Sampler Hammer
 Weight: 140 lbs.
 Fall: 30 in.
 Hammer Type: Automatic

Ground Elev.: _____ Boring Advance By: HW (4") Casing/3 7/8" Wet Rotary

Start Date: 11/12/2020 Finish Date: 11/12/2020

Groundwater Observations			
Date	Time	Depth	Casing
11/12/2020	AM	17.0'	18.0'
11/12/2020	PM	*22.5'	18.0'
11/12/2020	PM	*24.7'	18.0'
11/12/2020	PM	DRY	CAVED

Borehole caved at 20.0 feet. *May be affected by water utilized to advance the borehole.

DEPTH	METHOD OF ADVANCE	SAMPLE NO.	DEPTH OF SAMPLE		SAMPLE TYPE	BLOWS ON SAMPLER PER 6" 2" O.D. SAMPLER	DEPTH OF CHANGE	CLASSIFICATION OF MATERIAL f - fine m - medium c - coarse and - 35-50% some - 20-35% little - 10-20% trace - 0-10%	Recovery (Inches)
			From	To					
1									
2									
3									
4									
5	C A S I N G	1	5.0	7.0	SS	3 8 5 4	7.0	Black and Brown cmf GRAVEL; some cmf SAND; little SILT (moist, non-plastic)	14
6									
7		2	7.0	9.0	SS	13 6 24 26		Light Brown c-m+f SAND; trace SILT; trace f GRAVEL (moist, non-plastic) w = 15.8%	14
8									
9		3	9.0	11.0	SS	10 14 20 19	13.0	Light Brown cmf SAND; some SILT; trace f GRAVEL (wet, non-plastic)	10
10									
11		4	11.0	13.0	SS	8 11 15 20		Light Brown cmf SAND; little SILT; trace f GRAVEL (wet, non-plastic)	6
12									
13		5	13.0	15.0	SS	10 9 21 18	23.0	Orange cmf SAND; some c+f GRAVEL; little SILT (wet, non-plastic) w = 12.0%	8
14									
15									
16									
17								Advanced casing to 18.0 feet and began advancing 3 7/8" tri-cone roller bit wet rotary open hole within the borehole.	
18	WET R O T A R Y	6	18.0	20.0	SS	11 12 25 26	23.0	Light Brown c-m+f SAND; little mf+ GRAVEL; trace SILT (wet, non-plastic)	14
19									
20		7	20.0	22.0	SS	12 12 15 15		Light Brown c-m+f SAND; little mf+ GRAVEL; trace SILT (wet, non-plastic) w = 14.2%, PL = NP, LL = NP, PI = NP	6
21									
22									
23									
24		8	24.0	26.0	SS	11 10 11 12		Light Brown cmf SAND; some SILT (wet, non-plastic)	6
25									

SS Split Spoon Sample
 NX Rock Core
 SH Undisturbed Sample (Shelby Tube)
 Estimated Groundwater

Drillers: Scott McGregor; Kevin Jones
 Inspector: _____

ATL-LOG1 LL CD4827 POWER ENGINEERS - SAG HARBOR.GPJ ATL4-08.GDT 12/22/20

ATLANTIC TESTING LABORATORIES, Limited

Subsurface Investigation

Boring No.: BH-9

Report No.: CD4827E-01-12-20

Sheet 2 of 2

DEPTH	METHOD OF ADVANCE	SAMPLE NO.	DEPTH OF SAMPLE		SAMPLE TYPE	BLOWS ON SAMPLER PER 6" 2" O.D. SAMPLER	DEPTH OF CHANGE	CLASSIFICATION OF MATERIAL	RECOVERY (inches)
			From	To					
26									
27									
28									
29		9	29.0	31.0	SS	10 11 14 15		Light Brown cmf SAND; some SILT; little f GRAVEL (wet, non-plastic)	8
30									
31									
32									
33									
34		10	34.0	36.0	SS	14 12 24 29		Light Brown cmf SAND; some SILT; trace f GRAVEL; trace CLAY (wet, very slightly plastic) w = 12.4%	10
35									
36									
37									
38		11	38.0	40.0	SS	19 19 23 27		Light Brown cmf SAND; some SILT; trace f GRAVEL; trace CLAY (wet, very slightly plastic)	16
39							40.0		
40		12	40.0	42.0	SS	20 23 19 24		Orangish-Brown cmf SAND; and cmf GRAVEL; little SILT (wet, non-plastic)	10
41							42.0		
42									
43								Boring terminated at 42.0 feet.	
44									
45								Notes:	
46								1. Borehole backfilled with on-site soils.	
47								2. A brass-lined 3" split spoon sampler was utilized to obtain samples S-6 and S-11. All other samples were collected with a 2" split spoon sampler.	
48								3. Bulk sample BS-1 was collected from auger cuttings at a depth of 10.0 feet.	
49									
50									
51									
52									
53									
54									
55									
56									
57									
58									
59									
60									
61									
62									

ATL-LOG1 LL CD4827 POWER ENGINEERS - SAG HARBOR.GPJ ATL4-08.GDT 12/22/20

APPENDIX D

GEOTECHNICAL DESIGN PARAMETERS SUMMARY TABLES

Appendix D
Geotechnical Design Parameters Summary Tables
Proposed 69kV UG Transmission Circuits
Bridgehampton 9R to Buell 9E Substations
Sag Harbor to East Hampton, Suffolk County, New York
ATL No. CD4827E-01-05-20 Rev. 1

Soil Boring BH-1

Soil Layer	Description of Material	General USCS Symbol	General Soil Type	Depth to Bottom of Layer (ft)	Moist Unit Weight (pcf)	Effective Friction Angle, ϕ (deg)	Cohesion (ksf)	Estimated Average Elastic Modulus, E_s (ksi)
1	Loose to M. Compact SAND	SP/SM	Cohesionless	27	115	28	0	3.5
2	M. Compact SILT and fine SAND	SM/ML	Cohesionless	52	110	26	0	1
3	M. Compact CLAYEY SAND	SC	Cohesive	57	115	24	1.5	1
4	V. Compact SAND and GRAVEL	SM/SP GM/GP	Cohesionless	82	130	36	0	10
5	V. Compact CLAYEY SAND	SC	Cohesive	87	120	30	3.5	4
6	V. Compact SAND	SM	Cohesionless	101 ⁽¹⁾	120	32	0	7.5

⁽¹⁾ Boring termination depth

Subsurface Water Observations

Date	Time	Freestanding Water Depth (ft)	Notes
5/12/20	AM	6.4 ⁽¹⁾	Freestanding water first recorded
5/12/20-5/14/20	AM/PM	22.3 – 42.4 ⁽¹⁾	Freestanding water depths during borehole advancement
5/14/20	PM	17.2 ⁽¹⁾	Freestanding water depth at the completion of drilling ⁽²⁾

⁽¹⁾ May be affected by water utilized to advance the borehole

⁽²⁾ Borehole caved at 25.7 feet

Appendix D
Geotechnical Design Parameters Summary Tables
Proposed 69kV UG Transmission Circuits
Bridgehampton 9R to Buell 9E Substations
Sag Harbor to East Hampton, Suffolk County, New York
ATL No. CD4827E-01-05-20 Rev. 1

Soil Boring BH-2

Soil Layer	Description of Material	General USCS Symbol	General Soil Type	Depth to Bottom of Layer (ft)	Moist Unit Weight (pcf)	Effective Friction Angle, ϕ (deg)	Cohesion (ksf)	Estimated Average Elastic Modulus, E_s (ksi)
1	Loose to M. Compact GRAVELLY SAND	SW/SM	Cohesionless	22	115	30	0	2.75
2	M. Compact SILTY SAND	SM	Cohesionless	82	115	28	0	2.5
3	Compact SILTY SAND with GRAVEL	SM	Cohesionless	102 ⁽¹⁾	125	32	0	3.5

⁽¹⁾ Boring termination depth

Subsurface Water Observations

Date	Time	Freestanding Water Depth (ft)	Notes
9/23/20	PM	9.7 ⁽¹⁾	Freestanding water first recorded
9/23/20-9/24/20	AM/PM	11.1 – 22.9 ⁽¹⁾	Freestanding water depths during borehole advancement
9/24/20	PM	22.8 ⁽¹⁾	Freestanding water depth at the completion of drilling ⁽²⁾

⁽¹⁾ May be affected by water utilized to advance the borehole

⁽²⁾ Borehole caved at 101.6 feet

Appendix D
Geotechnical Design Parameters Summary Tables
Proposed 69kV UG Transmission Circuits
Bridgehampton 9R to Buell 9E Substations
Sag Harbor to East Hampton, Suffolk County, New York
ATL No. CD4827E-01-05-20 Rev. 1

Soil Boring BH-3

Soil Layer	Description of Material	General USCS Symbol	General Soil Type	Depth to Bottom of Layer (ft)	Moist Unit Weight (pcf)	Effective Friction Angle, Ø (deg)	Cohesion (ksf)	Estimated Average Elastic Modulus, E _s (ksi)
1	Loose to M. Compact SILTY SAND	SM	Cohesionless	42	115	28	0	2
2	M. Compact to Compact SILTY fine SAND	SM	Cohesionless	78	115	28	0	2
3	M. Compact to Compact SILTY SAND with CLAY	SM-SC	Cohesionless	101 ⁽¹⁾	120	30	0	2.5

⁽¹⁾ Boring termination depth

Subsurface Water Observations

Date	Time	Freestanding Water Depth (ft)	Notes
9/22/20	AM	10.8 ⁽¹⁾	Freestanding water first recorded
9/22/20-9/23/20	AM/PM	18.1 – 18.6 ⁽¹⁾	Freestanding water depth during borehole advancement
9/23/20	AM	19.4 ⁽¹⁾	Freestanding water depth at the completion of drilling

⁽¹⁾ May be affected by water utilized to advance the borehole

APPENDIX E

LABORATORY TEST REPORTS

SPLIT SPOON SAMPLES



ATLANTIC TESTING LABORATORIES

WBE certified company

LABORATORY DETERMINATION OF MOISTURE CONTENT OF SOILS

ASTM D 2216

PROJECT INFORMATION

Client: Power Engineers, Inc.

ATL Report No.: CD4827SL-01-07-20

Project: Proposed 69 KV (UG) Transmission Cable Route

Report Date: July 10, 2020

Bridgehamton SS to Buell SS

Date Received: July 6, 2020

Sag Harbor, Suffolk County, New York

TEST DATA

Boring No.	Sample No.	Depth (ft)	Moisture Content (%)
BH-1	S-11	34.0-36.0	35.2
	S-15 ¹	54.0-56.0	20.5
	S-19 ¹	74.0-76.0	13.2
	S-24 ¹	99.0-101.0	22.9
BH-4	S-6 ¹	10.0-12.0	5.3
BH-6	S-3	4.0-6.0	11.3
BH-8	S-5 ¹	8.0-10.0	4.4

REMARKS

1. Sample mass was less than the minimum mass outlined in the referenced test method.

Reviewed By:

Judith Ames

Date: 07/10/20



ATLANTIC TESTING LABORATORIES

WBE certified company

LABORATORY DETERMINATION OF MOISTURE CONTENT OF SOILS

ASTM D 2216

PROJECT INFORMATION

Client: Power Engineers, Inc.

ATL Report No.: CD4827SL-02-10-20

Project: Proposed 69 KV (UG) Transmission Cable Route

Report Date: October 22, 2020

Bridgehamton SS to Buell SS

Date Received: October 19, 2020

Sufflok County, New York

TEST DATA

Boring No.	Sample No.	Depth (ft)	Moisture Content (%)
BH-2	S-5 ¹	11.0-13.0	7.4
	S-9 ¹	29.0-31.0	12.1
	S-19	74.0-76.0	25.5
	S-22 ¹	89.0-91.0	13.8
BH-3	S-5 ¹	11.0-13.0	9.8
	S-11 ¹	34.0-36.0	16.5
	S-15	54.0-56.0	21.6
	S-22 ¹	84.0-86.0	19.2

REMARKS

1. Sample mass was less than the minimum mass outlined in the referenced test method.

Reviewed By:



Date: 10/22/20



ATLANTIC TESTING LABORATORIES

WBE certified company

LABORATORY DETERMINATION OF MOISTURE CONTENT OF SOILS

ASTM D 2216

PROJECT INFORMATION

Client: Power Engineers, Inc.

ATL Report No.: CD4827SL-03-12-20

Project: Proposed 69 KV (UG) Transmission Cable Route

Report Date: December 3, 2020

Bridgehamton SS to Buell SS

Date Received: December 1, 2020

Sag Harbor, Suffolk County, New York

TEST DATA

Boring No.	Sample No.	Depth (ft)	Moisture Content (%)
BH-9	S-2	7.0-9.0	15.8
	S-5 ¹	13.0-15.0	12.0
	S-7 ¹	20.0-22.0	14.2
	S-10 ¹	34.0-36.0	12.4

REMARKS

1. Sample mass was less than the minimum mass outlined in the referenced test method.

Reviewed By:

Date: 12/03/20



Particle Size Distribution Report

Project: 69KV (UG) Transmission Cable Route, Sag Harbor

Report No.: CD4827SL-01-07-20

Client: Power Engineers, Inc.


Date: 07/10/20

Sample No: BH-1, S-11

Source of Sample: Boring Sample

Location: In-place

Elev./Depth: 34.0-36.0'



% Cobbles	% Gravel		% Sand			% Fines	
	Coarse	Fine	Coarse	Medium	Fine	Silt	Clay
0	0	0	0	9	22	69	

SIEVE SIZE	PERCENT FINER	SPEC.* PERCENT	OUT OF SPEC. (X)
#4	100		
#10	100		
#40	91		
#200	69		

Soil Description

Black SILT; some mf+ SAND

Atterberg Limits

PL= --

LL= --

PI= --

Coefficients

D₈₅= 0.2405

D₆₀=

D₅₀=

D₃₀=

D₁₅=

D₁₀=

C_u=

C_c=

Classification

USCS=

AASHTO=

Remarks

Moisture Content = 35.2%

* (no specification provided)

ATLANTIC TESTING LABORATORIES, LIMITED

Figure

Reviewed by: Judez Ames

Date: 07/10/20



Particle Size Distribution Report

Project: 69KV (UG) Transmission Cable Route, Sag Harbor

Report No.: CD4827SL-01-07-20

Client: Power Engineers, Inc.


Date: 07/10/20

Sample No: BH-1, S-15

Source of Sample: Boring Sample

Location: In-place

Elev./Depth: 54.0-56.0'



% Cobbles	% Gravel		% Sand			% Fines	
	Coarse	Fine	Coarse	Medium	Fine	Silt	Clay
0	3	7	7	19	22	14	28

SIEVE SIZE	PERCENT FINER	SPEC.* PERCENT	OUT OF SPEC. (X)
1"	100		
1/2"	94		
#4	90		
#10	83		
#40	64		
#200	42		

Soil Description

Reddish-Brown c-mf SAND; some CLAY; little SILT; trace mf GRAVEL

Atterberg Limits

PL= 20 LL= 42 PI= 22

Coefficients

D₈₅= 2.3512 D₆₀= 0.3296 D₅₀= 0.1642
D₃₀= 0.0068 D₁₅= 0.0018 D₁₀=
C_u= C_c=

Classification

USCS= SC AASHTO= A-7-6(5)

Remarks

Moisture Content = 20.5%

* (no specification provided)

ATLANTIC TESTING LABORATORIES, LIMITED

Figure

Reviewed by: Judith Ames

Date: 07/10/20



Particle Size Distribution Report

Project: 69KV (UG) Transmission Cable Route, Sag Harbor

Report No.: CD4827SL-01-07-20

Client: Power Engineers, Inc.


Date: 07/10/20

Sample No: BH-1, S-19

Source of Sample: Boring Sample

Location: In-place

Elev./Depth: 74.0-76.0'



% Cobbles	% Gravel		% Sand			% Fines	
	Coarse	Fine	Coarse	Medium	Fine	Silt	Clay
0	0	2	30	59	7	2	

SIEVE SIZE	PERCENT FINER	SPEC.* PERCENT	OUT OF SPEC. (X)
1/2"	100		
#4	98		
#10	68		
#40	9		
#200	2.0		

* (no specification provided)

Soil Description

Greyish-White cm+f- SAND; trace f GRAVEL; trace SILT

Atterberg Limits

PL= -- LL= -- PI= --

Coefficients

D₈₅= 3.0307 D₆₀= 1.6884 D₅₀= 1.3468
D₃₀= 0.8316 D₁₅= 0.5349 D₁₀= 0.4422
C_u= 3.82 C_c= 0.93

Classification

USCS= SP AASHTO=

Remarks

Moisture Content = 13.2%

Figure

ATLANTIC TESTING LABORATORIES, LIMITED

Reviewed by: Judith Ames

Date: 07/10/20



Particle Size Distribution Report

Project: 69KV (UG) Transmission Cable Route, Sag Harbor

Report No.: CD4827SL-01-07-20

Client: Power Engineers, Inc.


Date: 07/10/20

Sample No: BH-1, S-24

Source of Sample: Boring Sample

Location: In-place

Elev./Depth: 99.0-101.0'



% Cobbles	% Gravel		% Sand			% Fines	
	Coarse	Fine	Coarse	Medium	Fine	Silt	Clay
0	0	0	5	2	17	76	

SIEVE SIZE	PERCENT FINER	SPEC.* PERCENT	OUT OF SPEC. (X)
1/2"	100		
#4	100		
#10	95		
#40	93		
#200	76		

* (no specification provided)

Soil Description

Light Brown SILT; some cm-ft+ SAND

Atterberg Limits

PL= -- LL= -- PI= --

Coefficients

D₈₅= 0.1537 D₆₀= D₅₀=
D₃₀= D₁₅= D₁₀=
C_u= C_c=

Classification

USCS= AASHTO=

Remarks

Moisture Content = 22.9%

Figure

ATLANTIC TESTING LABORATORIES, LIMITED

Reviewed by: Judith Ames

Date: 07/10/20



ATLANTIC TESTING LABORATORIES

Particle Size Distribution Report

Project: 69KV (UG) Trans. Cable Rt, Bridgehampton to Buell SS **Report No.:** CD4827SL-02-10-20

Client: Power Engineers, Inc.


Date: 10/22/20

Sample No: BH-2, S-5

Source of Sample: Boring Sample

Location: In-place

Elev./Depth: 11.0-13.0'



% Cobbles	% Gravel		% Sand			% Fines	
	Coarse	Fine	Coarse	Medium	Fine	Silt	Clay
0	8	33	15	18	21	5	

SIEVE SIZE	PERCENT FINER	SPEC.* PERCENT	OUT OF SPEC. (X)
1"	100		
1/2"	81		
#4	59		
#10	44		
#40	26		
#200	5.3		

* (no specification provided)

Soil Description

Brown cmf SAND; and mf GRAVEL; trace SILT

Atterberg Limits

PL= -- LL= -- PI= --

Coefficients

D₈₅= 14.6255 D₆₀= 4.9698 D₅₀= 2.8936
D₃₀= 0.5937 D₁₅= 0.1610 D₁₀= 0.1085
C_u= 45.81 C_c= 0.65

Classification

USCS= AASHTO=

Remarks

Moisture Content = 7.4%

Figure

ATLANTIC TESTING LABORATORIES, LIMITED

Reviewed by: Judith Cones

Date: 10/23/20



ATLANTIC TESTING LABORATORIES

Particle Size Distribution Report

Project: 69KV (UG) Trans. Cable Rt, Bridgehampton to Buell SS **Report No.:** CD4827SL-02-10-20

Client: Power Engineers, Inc.


Date: 10/22/20

Sample No: BH-2, S-9

Source of Sample: Boring Sample

Location: In-place

Elev./Depth: 29.0-31.0'



% Cobbles	% Gravel		% Sand			% Fines	
	Coarse	Fine	Coarse	Medium	Fine	Silt	Clay
0	3	7	4	25	40	21	

SIEVE SIZE	PERCENT FINER	SPEC.* PERCENT	OUT OF SPEC. (X)
1"	100		
1/2"	94		
#4	90		
#10	86		
#40	61		
#200	21		

* (no specification provided)

Soil Description

Brown c-mf+ SAND; little SILT; trace mf GRAVEL

Atterberg Limits

PL= NP

LL= NP

PI= NP

Coefficients

D₈₅= 1.8815

D₆₀= 0.4034

D₅₀= 0.2558

D₃₀= 0.1095

D₁₅=

D₁₀=

C_u=

C_c=

Classification

USCS= SM

AASHTO= A-2-4(0)

Remarks

Moisture Content = 12.1%

Figure

ATLANTIC TESTING LABORATORIES, LIMITED

Reviewed by:

Judez Ames

Date:

10/23/20



ATLANTIC TESTING LABORATORIES

Particle Size Distribution Report

Project: 69KV (UG) Trans. Cable Rt, Bridgehampton to Buell SS **Report No.:** CD4827SL-02-10-20

Client: Power Engineers, Inc.


Date: 10/22/20

Sample No: BH-2, S-19

Source of Sample: Boring Sample

Location: In-place

Elev./Depth: 74.0-76.0'



% Cobbles	% Gravel		% Sand			% Fines	
	Coarse	Fine	Coarse	Medium	Fine	Silt	Clay
0	0	0	9	66	22	3	

SIEVE SIZE	PERCENT FINER	SPEC.* PERCENT	OUT OF SPEC. (X)
1/2"	100		
#4	100		
#10	91		
#40	25		
#200	2.6		

* (no specification provided)

Soil Description

Light Brown c-m+f SAND; trace SILT

Atterberg Limits

PL= -- LL= -- PI= --

Coefficients

D₈₅= 1.6565 D₆₀= 0.9253 D₅₀= 0.7525
D₃₀= 0.4829 D₁₅= 0.2999 D₁₀= 0.2323
C_u= 3.98 C_c= 1.08

Classification

USCS= SP AASHTO=

Remarks

Moisture Content = 25.5%

Figure

ATLANTIC TESTING LABORATORIES, LIMITED

Reviewed by: Judith Ames

Date: 10/23/20



ATLANTIC TESTING LABORATORIES

Particle Size Distribution Report

Project: 69KV (UG) Trans. Cable Rt, Bridgehampton to Buell SS **Report No.:** CD4827SL-02-10-20

Client: Power Engineers, Inc.


Date: 10/22/20

Sample No: BH-2, S-22

Source of Sample: Boring Sample

Location: In-place

Elev./Depth: 89.0-91.0'



% Cobbles	% Gravel		% Sand			% Fines	
	Coarse	Fine	Coarse	Medium	Fine	Silt	Clay
0	12	4	3	29	41	11	

SIEVE SIZE	PERCENT FINER	SPEC.* PERCENT	OUT OF SPEC. (X)
2"	100		
1"	88		
1/2"	88		
#4	84		
#10	81		
#40	52		
#200	11		

* (no specification provided)

Soil Description

Brown c-mf+ SAND; little c+f GRAVEL; trace CLAY; trace SILT

Atterberg Limits

PL= -- LL= -- PI= --

Coefficients

D₈₅= 5.8846 D₆₀= 0.5863 D₅₀= 0.3826
D₃₀= 0.1648 D₁₅= 0.0879 D₁₀=
C_u= C_c=

Classification

USCS= AASHTO=

Remarks

Moisture Content = 13.8%

ATLANTIC TESTING LABORATORIES, LIMITED

Figure

Reviewed by: Judey Ames

Date: 10/23/20



ATLANTIC TESTING LABORATORIES

Particle Size Distribution Report

Project: 69KV (UG) Trans. Cable Rt, Bridgehampton to Buell SS **Report No.:** CD4827SL-02-10-20

Client: Power Engineers, Inc.


Date: 10/22/20

Sample No: BH-3, S-5

Source of Sample: Boring Sample

Location: In-place

Elev./Depth: 11.0-13.0'



% Cobbles	% Gravel		% Sand			% Fines	
	Coarse	Fine	Coarse	Medium	Fine	Silt	Clay
0	1	21	13	25	34	6	

SIEVE SIZE	PERCENT FINER	SPEC.* PERCENT	OUT OF SPEC. (X)
1"	100		
1/2"	95		
#4	78		
#10	65		
#40	40		
#200	5.5		

* (no specification provided)

Soil Description

Light Brown c-mf SAND; some mf+ GRAVEL; trace SILT

Atterberg Limits

PL= -- LL= -- PI= --

Coefficients

D₈₅= 6.8255 D₆₀= 1.4023 D₅₀= 0.7559
D₃₀= 0.2533 D₁₅= 0.1193 D₁₀= 0.0933
C_u= 15.03 C_c= 0.49

Classification

USCS= AASHTO=

Remarks

Moisture Content = 9.8%

Figure

ATLANTIC TESTING LABORATORIES, LIMITED

Reviewed by:

Judee Ames

Date:

10/23/20



ATLANTIC TESTING LABORATORIES

Particle Size Distribution Report

Project: 69KV (UG) Trans. Cable Rt, Bridgehampton to Buell SS **Report No.:** CD4827SL-02-10-20

Client: Power Engineers, Inc.


Date: 10/22/20

Sample No: BH-3, S-11

Source of Sample: Boring Sample

Location: In-place

Elev./Depth: 34.0-36.0'



% Cobbles	% Gravel		% Sand			% Fines	
	Coarse	Fine	Coarse	Medium	Fine	Silt	Clay
0	0	1	8	51	37	3	

SIEVE SIZE	PERCENT FINER	SPEC.* PERCENT	OUT OF SPEC. (X)
1/2"	100		
#4	99		
#10	91		
#40	40		
#200	2.7		

Soil Description

Light Brown c-m+f SAND; trace SILT; trace f GRAVEL

Atterberg Limits

PL= -- LL= -- PI= --

Coefficients

D₈₅= 1.536
D₆₀= 0.7372
D₃₀= 0.2985
C_u= 6.35
D₅₀= 0.5622
D₁₅= 0.1528
D₁₀= 0.1161
C_c= 1.04

Classification

USCS= SW AASHTO=

Remarks

Moisture Content = 16.5%

* (no specification provided)

ATLANTIC TESTING LABORATORIES, LIMITED

Figure

Reviewed by: Judith Ames

Date: 10/23/20



ATLANTIC TESTING LABORATORIES

Particle Size Distribution Report

Project: 69KV (UG) Trans. Cable Rt, Bridgehampton to Buell SS **Report No.:** CD4827SL-02-10-20

Client: Power Engineers, Inc.


Date: 10/23/20

Sample No: BH-3, S-15

Source of Sample: Boring Sample

Location: In-place

Elev./Depth: 54.0-56.0'



% Cobbles	% Gravel		% Sand			% Fines	
	Coarse	Fine	Coarse	Medium	Fine	Silt	Clay
0	0	0	3	12	48	37	

SIEVE SIZE	PERCENT FINER	SPEC.* PERCENT	OUT OF SPEC. (X)
#4	100		
#10	97		
#40	85		
#200	37		

* (no specification provided)

Soil Description

Brown c-mf+ SAND; and SILT

Atterberg Limits

PL= NP

LL= NP

PI= NP

Coefficients

D₈₅= 0.4242

D₆₀= 0.1541

D₅₀= 0.1119

D₃₀=

D₁₅=

D₁₀=

C_u=

C_c=

Classification

USCS= SM

AASHTO= A-4(0)

Remarks

Moisture Content = 21.6%

Figure

ATLANTIC TESTING LABORATORIES, LIMITED

Reviewed by:

Judith Ames

Date:

10/23/20



Particle Size Distribution Report

Project: 69KV (UG) Trans. Cable Rt, Bridgehampton to Buell SS **Report No.:** CD4827SL-02-10-20

Client: Power Engineers, Inc.


Date: 10/23/20

Sample No: BH-3, S-22

Source of Sample: Boring Sample

Location: In-place

Elev./Depth: 84.0-86.0'



% Cobbles	% Gravel		% Sand			% Fines	
	Coarse	Fine	Coarse	Medium	Fine	Silt	Clay
0	1	5	2	19	43	30	

SIEVE SIZE	PERCENT FINER	SPEC.* PERCENT	OUT OF SPEC. (X)
1"	100		
1/2"	97		
#4	94		
#10	92		
#40	73		
#200	30		

* (no specification provided)

Soil Description

Greyish-Brown c-mf+ SAND; little SILT; little CLAY; little mf GRAVEL

Atterberg Limits

PL= -- LL= -- PI= --

Coefficients

D₈₅= 0.8833 D₆₀= 0.2365 D₅₀= 0.1583
D₃₀= D₁₅= D₁₀=
C_u= C_c=

Classification

USCS= AASHTO= A-2-4(0)

Remarks

Moisture Content = 19.2%

Figure

ATLANTIC TESTING LABORATORIES, LIMITED

Reviewed by: Judith Ames

Date: 10/23/20



Particle Size Distribution Report

Project: 69KV (UG) Transmission Cable Route, Sag Harbor

Report No.: CD4827SL-01-07-20

Client: Power Engineers, Inc.


Date: 07/10/20

Sample No: BH-4, S-6

Source of Sample: Boring Sample

Location: In-place

Elev./Depth: 10.0-12.0'



% Cobbles	% Gravel		% Sand			% Fines	
	Coarse	Fine	Coarse	Medium	Fine	Silt	Clay
0	0	5	4	42	41	8	

SIEVE SIZE	PERCENT FINER	SPEC.* PERCENT	OUT OF SPEC. (X)
1"	100		
1/2"	99		
#4	95		
#10	91		
#40	49		
#200	8.1		

* (no specification provided)

Soil Description

Light Brown c-mf SAND; trace SILT; trace f GRAVEL

Atterberg Limits

PL= -- LL= -- PI= --

Coefficients

D₈₅= 1.4428 D₆₀= 0.6099 D₅₀= 0.4436
D₃₀= 0.2095 D₁₅= 0.1054 D₁₀= 0.0825
C_u= 7.39 C_c= 0.87

Classification

USCS= AASHTO=

Remarks

Moisture Content = 5.3%

Figure

ATLANTIC TESTING LABORATORIES, LIMITED

Reviewed by:

Judy Ames

Date:

07/10/20



Particle Size Distribution Report

Project: 69KV (UG) Transmission Cable Route, Sag Harbor

Report No.: CD4827SL-01-07-20

Client: Power Engineers, Inc.


Date: 07/10/20

Sample No: BH-6, S-3

Source of Sample: Boring Sample

Location: In-place

Elev./Depth: 4.0-6.0'



% Cobbles	% Gravel		% Sand			% Fines	
	Coarse	Fine	Coarse	Medium	Fine	Silt	Clay
0	0	0	0	9	61	30	

SIEVE SIZE	PERCENT FINER	SPEC.* PERCENT	OUT OF SPEC. (X)
#4	100		
#10	100		
#40	91		
#200	30		

* (no specification provided)

Soil Description

Light Brown m-f SAND; some SILT

Atterberg Limits

PL= -- LL= -- PI= --

Coefficients

D₈₅= 0.3307 D₆₀= 0.1541 D₅₀= 0.1197
D₃₀= D₁₅= D₁₀=
C_u= C_c=

Classification

USCS= AASHTO=

Remarks

Moisture Content = 11.3%

Figure

ATLANTIC TESTING LABORATORIES, LIMITED

Reviewed by:

Judge Amos

Date:

07/10/20



Particle Size Distribution Report

Project: 69KV (UG) Transmission Cable Route, Sag Harbor

Report No.: CD4827SL-01-07-20

Client: Power Engineers, Inc.


Date: 07/10/20

Sample No: BH-8, S-5

Source of Sample: Boring Sample

Location: In-place

Elev./Depth: 8.0-10.0'



% Cobbles	% Gravel		% Sand			% Fines	
	Coarse	Fine	Coarse	Medium	Fine	Silt	Clay
0	17	7	7	35	26	8	

SIEVE SIZE	PERCENT FINER	SPEC.* PERCENT	OUT OF SPEC. (X)
2"	100		
1"	85		
1/2"	81		
#4	76		
#10	69		
#40	34		
#200	8.2		

* (no specification provided)

Soil Description

Light Brown c-mf SAND; some c+mf GRAVEL; trace SILT

Atterberg Limits

PL= -- LL= -- PI= --

Coefficients

D₈₅= 24.8378 D₆₀= 1.2635 D₅₀= 0.8343
D₃₀= 0.3579 D₁₅= 0.1357 D₁₀= 0.0881
C_u= 14.34 C_c= 1.15

Classification

USCS= AASHTO=

Remarks

Moisture Content = 4.4%

Figure

ATLANTIC TESTING LABORATORIES, LIMITED

Reviewed by:

Judez Ames

Date:

07/10/20



ATLANTIC TESTING LABORATORIES

Particle Size Distribution Report

Project: 69KV (UG) Trans. Cable Rt, Bridgehampton to Buell SS **Report No.:** CD4827SL-03-12-20

Client: Power Engineers, Inc.


Date: 12/03/20

Sample No: BH-9, S-2

Source of Sample: Boring Sample

Location: In-place

Elev./Depth: 7.0-9.0'



GRAIN SIZE - mm.

% Cobbles	% Gravel		% Sand			% Fines	
	Coarse	Fine	Coarse	Medium	Fine	Silt	Clay
0	0	3	6	51	34	6	

SIEVE SIZE	PERCENT FINER	SPEC.* PERCENT	OUT OF SPEC. (X)
1/2"	100		
#4	97		
#10	91		
#40	40		
#80	12		
#200	6.4		

* (no specification provided)

Soil Description

Light Brown c-m+f SAND; trace SILT; trace f GRAVEL

Atterberg Limits

PL= -- LL= -- PI= --

Coefficients

D₈₅= 1.5086 D₆₀= 0.7066 D₅₀= 0.5477
D₃₀= 0.3278 D₁₅= 0.2022 D₁₀= 0.1542
C_u= 4.58 C_c= 0.99

Classification

USCS= AASHTO=

Remarks

Moisture Content= 15.8%

Figure

ATLANTIC TESTING LABORATORIES, LIMITED

Reviewed by:

Date: 12/3/20



ATLANTIC TESTING LABORATORIES

Particle Size Distribution Report

Project: 69KV (UG) Trans. Cable Rt, Bridgehampton to Buell SS **Report No.:** CD4827SL-03-12-20

Client: Power Engineers, Inc.


Date: 12/03/20

Sample No: BH-9, S-7

Source of Sample: Boring Sample

Location: In-place

Elev./Depth: 20.0-22.0'



% Cobbles	% Gravel		% Sand			% Fines	
	Coarse	Fine	Coarse	Medium	Fine	Silt	Clay
0	0	11	20	37	28	4	

SIEVE SIZE	PERCENT FINER	SPEC.* PERCENT	OUT OF SPEC. (X)
1"	100		
1/2"	98		
#4	89		
#10	69		
#40	32		
#80	9		
#200	4.3		

* (no specification provided)

Soil Description

Light Brown c-m+f SAND; little mf+ GRAVEL; trace SILT

Atterberg Limits

PL= NP

LL= NP

PI= NP

Coefficients

D₈₅= 3.9201

D₆₀= 1.3575

D₅₀= 0.8747

D₃₀= 0.3989

D₁₅= 0.2339

D₁₀= 0.1855

C_u= 7.32

C_c= 0.63

Classification

USCS= SP

AASHTO= A-1-b

Remarks

Moisture Content= 14.2%

Figure

ATLANTIC TESTING LABORATORIES, LIMITED

Reviewed by:

Date: 12/3/20



ATLANTIC TESTING LABORATORIES

WBE certified company

LIQUID LIMIT, PLASTIC LIMIT, AND PLASTICITY INDEX OF SOIL ASTM D 4318

PROJECT INFORMATION

Client: Power Engineers, Inc.
Project: Proposed 69 KV (UG) Transmission Cable Route
Bridgehamton SS to Buell SS
Sag Harbor, Suffolk County, New York

ATL Report No.: CD4827SL-01-07-20
Report Date: July 10, 2020
Date Received: July 6, 2020

TEST DATA

Boring No.	Sample No.	LL	PL	PI
BH-1	S-15	42	20	22

SAMPLE INFORMATION

Boring No.	Sample No.	Maximum Grain Size (mm)	Estimated Amount of Sample Retained on No. 40 Sieve (%)	As Received Moisture Content (%)
BH-1	S-15	25.4	36	20.5

PREPARATION INFORMATION

Boring No.	Sample No.	Preparation	Method of Removing Oversized Material
BH-1	S-15	Air Dry	Pulverizing and Screening

EQUIPMENT INFORMATION

Liquid Limit Procedure:	Multipoint - Method A	☐	Single Point - Method B	☒
Liquid Limit Apparatus:	Manual	☒	Motor Driven	☐
Liquid Limit Grooving Tool Material:	Plastic	☒	Metal	☐
Liquid Limit Grooving Tool Shape:	Flat	☒	Curved (AASHTO Only)	☐
Plastic Limit:	Hand Rolled	☒	Mechanical Rolling Device	☐

Reviewed By: Judith Amos

Date: 07/10/20



ATLANTIC TESTING LABORATORIES

WBE certified company

LIQUID LIMIT, PLASTIC LIMIT, AND PLASTICITY INDEX OF SOIL ASTM D 4318

PROJECT INFORMATION

Client: Power Engineers, Inc.
Project: Proposed 69 KV (UG) Transmission Cable Route
Bridgehamton SS to Buell SS
Suffolk County, New York

ATL Report No.: CD4827SL-02-10-20
Report Date: October 23, 2020
Date Received: October 19, 2020

TEST DATA

Boring No.	Sample No.	LL	PL	PI
BH-2	S-9	NP	NP	NP
BH-3	S-15	NP	NP	NP

SAMPLE INFORMATION

Boring No.	Sample No.	Maximum Grain Size (mm)	Estimated Amount of Sample Retained on No. 40 Sieve (%)	As Received Moisture Content (%)
BH-2	S-9	25.4	39	12.1
BH-3	S-15	4.76	15	21.6

PREPARATION INFORMATION

Boring No.	Sample No.	Preparation	Method of Removing Oversized Material
BH-2	S-9	Air Dry	Pulverizing and Screening
BH-3	S-15	Air Dry	Pulverizing and Screening

EQUIPMENT INFORMATION

Liquid Limit Procedure:	Multipoint - Method A	☐	Single Point - Method B	☒
Liquid Limit Apparatus:	Manual	☒	Motor Driven	☐
Liquid Limit Grooving Tool Material:	Plastic	☒	Metal	☐
Liquid Limit Grooving Tool Shape:	Flat	☒	Curved (AASHTO Only)	☐
Plastic Limit:	Hand Rolled	☒	Mechanical Rolling Device	☐

Reviewed By: Judith Ames

Date: 10/23/20



ATLANTIC TESTING LABORATORIES

WBE certified company

LIQUID LIMIT, PLASTIC LIMIT, AND PLASTICITY INDEX OF SOIL ASTM D 4318

PROJECT INFORMATION

Client: Power Engineers, Inc.

ATL Report No.: CD4827SL-03-12-20

Project: Proposed 69 KV (UG) Transmission Cable Route
Bridgehamton SS to Buell SS
Sag Harbor, Suffolk County, New York

Report Date: December 3, 2020

Date Received: December 1, 2020

TEST DATA

Boring No.	Sample No.	LL	PL	PI
BH-9	S-7	NP	NP	NP

SAMPLE INFORMATION


Boring No.	Sample No.	Maximum Grain Size (mm)	Estimated Amount of Sample Retained on No. 40 Sieve (%)	As Received Moisture Content (%)
BH-9	S-7	12.7	68	14.2

PREPARATION INFORMATION

Boring No.	Sample No.	Preparation	Method of Removing Oversized Material
BH-9	S-7	Air Dry	Pulverizing and Screening

EQUIPMENT INFORMATION

Liquid Limit Procedure:	Multipoint - Method A	☒	Single Point - Method B	☐
Liquid Limit Apparatus:	Manual	☒	Motor Driven	☐
Liquid Limit Grooving Tool Material:	Plastic	☒	Metal	☐
Liquid Limit Grooving Tool Shape:	Flat	☒	Curved (AASHTO Only)	☐
Plastic Limit:	Hand Rolled	☒	Mechanical Rolling Device	☐

Reviewed By: 

Date: 12/03/20

BULK SAMPLES



ATLANTIC TESTING LABORATORIES

Particle Size Distribution Report

Project: 69KV (UG) Trans. Cable Rt, Bridgehampton to Buell SS **Report No.:** CD4827SL-02-10-20

Client: Power Engineers, Inc.


Date: 10/06/20

Sample No: BH-2, BS-1

Source of Sample: Bulk Sample

Location: In-place

Elev./Depth: 5 ft



% Cobbles	% Gravel		% Sand			% Fines	
	Coarse	Fine	Coarse	Medium	Fine	Silt	Clay
0	11	19	3	18	45	4	

SIEVE SIZE	PERCENT FINER	SPEC.* PERCENT	OUT OF SPEC. (X)
3"	100		
2"	98		
1"	92		
1/2"	82		
#4	70		
#10	67		
#40	49		
#200	3.8		

* (no specification provided)

Soil Description

Light Brown c-mf+ SAND; some cmf GRAVEL; trace SILT

Atterberg Limits

PL= -- LL= -- PI= --

Coefficients

D₈₅= 15.0731 D₆₀= 0.8851 D₅₀= 0.4580
D₃₀= 0.1906 D₁₅= 0.1105 D₁₀= 0.0928
C_u= 9.54 C_c= 0.44

Classification

USCS= SP AASHTO=

Remarks

Moisture Content = 2.3%

Figure


ATLANTIC TESTING LABORATORIES, LIMITED

Reviewed by: Judith Ames

Date: 10/06/20



COMPACTION TEST REPORT



Test specification: ASTM D 1557-12 Method B Modified
ASTM D4718-15 Oversize Corr. Applied to Each Test Point

Elev/ Depth	Classification		Received Moist.	Sp.G.	LL	PL	PI	% > 3/8 in.
	USCS	AASHTO						
5 ft	SP		2.3	2.65	--	--	--	22

ROCK CORRECTED TEST RESULTS

Maximum dry density = 125.7 pcf

Optimum moisture = 8.6 %

MATERIAL DESCRIPTION

Light Brown c-mf+ SAND; some cmf
GRAVEL; trace SILT

Report No.: CD4827SL-02-10-20 Client: Power Engineers, Inc.

Project: 69KV (UG) Transmission Cable Route, Bridgehampton SS to Buell SS

Sample No.: BH-2, BS-1 Source of Sample: Bulk Sample

Location: In-place

Date: 10/06/20

ATLANTIC TESTING LABORATORIES, LIMITED

Canton, New York

Remarks:

Moist Preparation

Rammer: Manual

Specific Gravity: Assumed

Reviewed by:

Judith Ames

Date: 10/06/20



ATLANTIC TESTING LABORATORIES

Particle Size Distribution Report

Project: 69KV (UG) Trans. Cable Rt, Bridgehampton to Buell SS **Report No.:** CD4827SL-02-10-20

Client: Power Engineers, Inc.


Date: 10/06/20

Sample No: BH-3, BS-1

Source of Sample: Bulk Sample

Location: In-place

Elev./Depth: 10 ft



% Cobbles	% Gravel		% Sand			% Fines	
	Coarse	Fine	Coarse	Medium	Fine	Silt	Clay
0	9	9	4	30	47	1	

SIEVE SIZE	PERCENT FINER	SPEC.* PERCENT	OUT OF SPEC. (X)
2"	100		
1"	94		
1/2"	87		
#4	82		
#10	78		
#40	48		
#200	1.0		

* (no specification provided)

Soil Description

Light Brown c-mf SAND; little cmf GRAVEL; trace SILT

Atterberg Limits

PL= -- LL= -- PI= --

Coefficients

D₈₅= 10.1647 D₆₀= 0.6968 D₅₀= 0.4643
D₃₀= 0.2170 D₁₅= 0.1250 D₁₀= 0.1042
C_u= 6.69 C_c= 0.65

Classification

USCS= SP AASHTO=

Remarks

Moisture Content = 2.8%

Figure


ATLANTIC TESTING LABORATORIES, LIMITED

Reviewed by: Judith Ames

Date: 10/06/20



COMPACTION TEST REPORT



Test specification: ASTM D 1557-12 Method A Modified
ASTM D4718-15 Oversize Corr. Applied to Each Test Point

Elev/ Depth	Classification		Received Moist.	Sp.G.	LL	PL	PI	% > #4
	USCS	AASHTO						
10 ft	SP		2.8	2.65	--	--	--	18

ROCK CORRECTED TEST RESULTS

Maximum dry density = 115.5 pcf
Optimum moisture = 9.4 %

MATERIAL DESCRIPTION

Light Brown c-mf SAND; little cmf
GRAVEL; trace SILT

Report No.: CD4827SL-02-10-20 Client: Power Engineers, Inc.
Project: 69KV (UG) Transmission Cable Route, Bridgehampton SS to Buell SS
Sample No.: BH-3, BS-1 Source of Sample: Bulk Sample
Location: In-place Date: 10/06/20

Remarks:
Moist Preparation

ATLANTIC TESTING LABORATORIES, LIMITED

Canton, New York

Rammer: Mechanical
Specific Gravity: Assumed

Reviewed by:

Judith Amos

Date: 10/06/20



ATLANTIC TESTING LABORATORIES

Particle Size Distribution Report

Project: 69KV (UG) Transmission Cable Route

Report No.: CD4827SL-01-06-20

Client: Power Engineers


Date: 06/02/20

Sample No: BH-4, BS-1

Source of Sample: Bulk Sample

Location: In-place

Elev./Depth: 5 ft



% Cobbles	% Gravel		% Sand			% Fines	
	Coarse	Fine	Coarse	Medium	Fine	Silt	Clay
0	1	7	2	23	52	15	

SIEVE SIZE	PERCENT FINER	SPEC.* PERCENT	OUT OF SPEC. (X)
2"	100		
1"	99		
1/2"	97		
#4	92		
#10	90		
#40	67		
#200	15		

* (no specification provided)

Soil Description

Brown c-mf+ SAND; little SILT; trace cmf+ GRAVEL

Atterberg Limits

PL= --

LL= --

PI= --

Coefficients

D₈₅= 1.1184

D₆₀= 0.3240

D₅₀= 0.2261

D₃₀= 0.1178

D₁₅=

D₁₀=

C_u=

C_c=

Classification

USCS=

AASHTO=

Remarks

Figure

ATLANTIC TESTING LABORATORIES, LIMITED


Reviewed by: Judith Ames

Date: 06/02/20



ATLANTIC TESTING LABORATORIES

COMPACTION TEST REPORT



Test specification: ASTM D 1557-12 Method A Modified
ASTM D4718-15 Oversize Corr. Applied to Each Test Point

Elev/ Depth	Classification		Received Moist.	Sp.G.	LL	PL	PI	% > #4
	USCS	AASHTO						
5 ft			6.0	2.65	--	--	--	8

ROCK CORRECTED TEST RESULTS		MATERIAL DESCRIPTION	
Maximum dry density = 124.0 pcf Optimum moisture = 8.0 %		Brown c-mf+ SAND; little SILT; trace cmf+ GRAVEL	
Report No.: CD4827SL-01-06-20 Client: Power Engineers Project: 69KV (UG) Transmission Cable Route - Bridgehamton SS to Buell SS Sample No.: BH-4, BS-1 Source of Sample: Bulk Sample Location: In-place Date: 06/02/20		Remarks: Moist Preparation	
ATLANTIC TESTING LABORATORIES, LIMITED Canton, New York		Rammer: Mechanical Specific Gravity: Assumed	

Reviewed by: Judith Ames

Date: 06/02/20



ATLANTIC TESTING LABORATORIES

Particle Size Distribution Report

Project: 69KV (UG) Transmission Cable Route

Report No.: CD4827SL-01-06-20

Client: Power Engineers


Date: 06/02/20

Sample No: BH-5, BS-2

Source of Sample: Bulk Sample

Location: In-place

Elev./Depth: 10 ft



% Cobbles	% Gravel		% Sand			% Fines	
	Coarse	Fine	Coarse	Medium	Fine	Silt	Clay
0	0	1	1	15	81	2	

SIEVE SIZE	PERCENT FINER	SPEC.* PERCENT	OUT OF SPEC. (X)
1"	100		
1/2"	99		
#4	99		
#10	98		
#40	83		
#200	2.1		

* (no specification provided)

Soil Description

Brown c-mf+ SAND; trace f GRAVEL; trace SILT

Atterberg Limits

PL= -- LL= -- PI= --

Coefficients

D₈₅= 0.4654 D₆₀= 0.2281 D₅₀= 0.1838
D₃₀= 0.1244 D₁₅= 0.0945 D₁₀= 0.0864
C_u= 2.64 C_c= 0.79

Classification

USCS= SP AASHTO=

Remarks

Figure

ATLANTIC TESTING LABORATORIES, LIMITED


Reviewed by: Judith Ames

Date: 06/02/20



ATLANTIC TESTING LABORATORIES

COMPACTION TEST REPORT



Test specification: ASTM D 1557-12 Method A Modified

Elev/ Depth	Classification		Received Moist.	Sp.G.	LL	PL	PI	% > #4
	USCS	AASHTO						
10 ft	SP		5.1	2.65	--	--	--	1
TEST RESULTS					MATERIAL DESCRIPTION			
Maximum dry density = 107.6 pcf Optimum moisture = 10.3 %					Brown c-mf+ SAND; trace f GRAVEL; trace SILT			
Report No.: CD4827SL-01-06-20 Client: Power Engineers Project: 69KV (UG) Transmission Cable Route - Bridgehamton SS to Buell SS Sample No.: BH-5, BS-2 Source of Sample: Bulk Sample Location: In-place Date: 06/02/20					Remarks: Moist Preparation			
ATLANTIC TESTING LABORATORIES, LIMITED Canton, New York					Rammer: Mechanical Specific Gravity: Assumed			

Reviewed by:

Judith Ames

Date: 06/02/20



ATLANTIC TESTING LABORATORIES

Particle Size Distribution Report

Project: 69KV (UG) Transmission Cable Route

Report No.: CD4827SL-01-06-20

Client: Power Engineers


Date: 06/02/20

Sample No: BH-6, BS-1

Source of Sample: Bulk Sample

Location: In-place

Elev./Depth: 5 ft



% Cobbles	% Gravel		% Sand			% Fines	
	Coarse	Fine	Coarse	Medium	Fine	Silt	Clay
0	1	7	3	21	53	15	

SIEVE SIZE	PERCENT FINER	SPEC.* PERCENT	OUT OF SPEC. (X)
2"	100		
1"	100		
1/2"	97		
#4	92		
#10	89		
#40	68		
#200	15		

* (no specification provided)

Soil Description

Brown c-mf+ SAND; little SILT; trace mf GRAVEL

Atterberg Limits

PL= -- LL= -- PI= --

Coefficients

D₈₅= 1.2473 D₆₀= 0.3092 D₅₀= 0.2170
D₃₀= 0.1159 D₁₅= D₁₀=
C_u= C_c=

Classification

USCS= AASHTO=

Remarks

Figure

ATLANTIC TESTING LABORATORIES, LIMITED


Reviewed by: Judith Ames

Date: 06/02/20



ATLANTIC TESTING LABORATORIES

COMPACTION TEST REPORT



Test specification: ASTM D 1557-12 Method A Modified
ASTM D4718-15 Oversize Corr. Applied to Each Test Point

Elev/ Depth	Classification		Received Moist.	Sp.G.	LL	PL	PI	% > #4
	USCS	AASHTO						
5 ft			7.4	2.65	--	--	--	8

ROCK CORRECTED TEST RESULTS		MATERIAL DESCRIPTION	
Maximum dry density = 120.7 pcf Optimum moisture = 8.6 %		Brown c-mf+ SAND; little SILT; trace mf GRAVEL	
Report No.: CD4827SL-01-06-20 Client: Power Engineers Project: 69KV (UG) Transmission Cable Route - Bridgehamton SS to Buell SS Sample No.: BH-6, BS-1 Source of Sample: Bulk Sample Location: In-place Date: 06/02/20		Remarks: Moist Preparation	
ATLANTIC TESTING LABORATORIES, LIMITED Canton, New York		Rammer: Mechanical Specific Gravity: Assumed	

Reviewed by: Judith Ames

Date: 06/02/20



ATLANTIC TESTING LABORATORIES

Particle Size Distribution Report

Project: 69KV (UG) Transmission Cable Route

Report No.: CD4827SL-01-06-20

Client: Power Engineers


Date: 06/02/20

Sample No: BH-7, BS-2

Source of Sample: Bulk Sample

Location: In-place

Elev./Depth: 10 ft



% Cobbles	% Gravel		% Sand			% Fines	
	Coarse	Fine	Coarse	Medium	Fine	Silt	Clay
0	1	4	5	47	40	3	

SIEVE SIZE	PERCENT FINER	SPEC.* PERCENT	OUT OF SPEC. (X)
1"	100		
1/2"	97		
#4	95		
#10	90		
#40	43		
#200	3.0		

* (no specification provided)

Soil Description

Brown c-mf SAND; trace SILT; trace mf GRAVEL

Atterberg Limits

PL= -- LL= -- PI= --

Coefficients

D₈₅= 1.5683 D₆₀= 0.7038 D₅₀= 0.5290
D₃₀= 0.2723 D₁₅= 0.1406 D₁₀= 0.1089
C_u= 6.46 C_c= 0.97

Classification

USCS= SP AASHTO=

Remarks

Figure

ATLANTIC TESTING LABORATORIES, LIMITED


Reviewed by: Judith Ames

Date: 06/02/20



ATLANTIC TESTING LABORATORIES

COMPACTION TEST REPORT



Test specification: ASTM D 1557-12 Method A Modified

Elev/ Depth	Classification		Received Moist.	Sp.G.	LL	PL	PI	% > #4
	USCS	AASHTO						
10 ft	SP		4.0	2.65	--	--	--	5

TEST RESULTS		MATERIAL DESCRIPTION
Maximum dry density = 108.6 pcf Optimum moisture = 13.2 %		Brown c-mf SAND; trace SILT; trace mf GRAVEL
Report No.: CD4827SL-01-06-20 Client: Power Engineers Project: 69KV (UG) Transmission Cable Route - Bridgehamton SS to Buell SS Sample No.: BH-7, BS-2 Source of Sample: Bulk Sample Location: In-place Date: 06/02/20 ATLANTIC TESTING LABORATORIES, LIMITED Canton, New York		Remarks: Moist Preparation Rammer: Mechanical Specific Gravity: Assumed

Reviewed by: Judey Ames

Date: 06/02/20



ATLANTIC TESTING LABORATORIES

Particle Size Distribution Report

Project: 69KV (UG) Trans. Cable Rt, Bridgehampton to Buell SS **Report No.:** CD4827SL-03-11-20

Client: Power Engineers, Inc.


Date: 11/20/20

Sample No: BH-9, BS-1

Source of Sample: Bulk Sample

Location: In-place

Elev./Depth: 10 ft



% Cobbles	% Gravel		% Sand			% Fines	
	Coarse	Fine	Coarse	Medium	Fine	Silt	Clay
0	3	11	4	16	23	43	

SIEVE SIZE	PERCENT FINER	SPEC.* PERCENT	OUT OF SPEC. (X)
2"	100		
1"	99		
3/4"	97		
1/2"	93		
3/8"	90		
1/4"	88		
#4	86		
#10	82		
#40	66		
#200	43		

Soil Description

Brown cmf SAND ; and SILT; little c-mf GRAVEL

Atterberg Limits

PL= --

LL= --

PI= --

Coefficients

D₈₅= 3.3798

D₆₀= 0.2744

D₅₀= 0.1289

D₃₀=

D₁₅=

D₁₀=

C_u=

C_c=

Classification

USCS= SM

AASHTO=

Remarks

Moisture Content= 10.5%

* (no specification provided)

ATLANTIC TESTING LABORATORIES, LIMITED

Figure


Reviewed by: Judith Ames

Date: 11/20/20



ATLANTIC TESTING LABORATORIES

COMPACTION TEST REPORT



Test specification: ASTM D 1557-12 Method A Modified
ASTM D4718-15 Oversize Corr. Applied to Each Test Point

Elev/ Depth	Classification		Received Moist.	Sp.G.	LL	PL	PI	% > #4
	USCS	AASHTO						
10 ft	SM		10.5	2.65	--	--	--	14

ROCK CORRECTED TEST RESULTS	MATERIAL DESCRIPTION
Maximum dry density = 131.9 pcf Optimum moisture = 7.0 %	Brown cmf SAND ; and SILT; little c-mf GRAVEL
Report No.: CD4827SL-03-11-20 Client: Power Engineers, Inc. Project: 69KV (UG) Trans. Cable Rt, Bridgehampton to Buell SS Sample No.: BH-9, BS-1 Source of Sample: Bulk Sample Location: In-place Date: 11/20/20	Remarks: Moist Preparation Rammer: Mechanical Specific Gravity: Assumed
ATLANTIC TESTING LABORATORIES, LIMITED Canton, New York	

Reviewed by: Judith Ames

Date: 11/20/20